


ITEM B-10 BOARD AS-BUILT MAPS FOR FEEDERS IN CONTRACT 6249







SEWERAGE AND WAITER BOARD OF NEW ORLEANS



ELECTRICAL
ENGINEERING DEPARTMENT





VICINITY MAP

REV. DATE DESCRIPTION BY

SEWERAGE AND WATER BOARD
OF NEW ORLEANS

CONTRACT 6198
1990 - CONSTRUCTION OF FEEDER "RSE"

TITLE SHEET

ETR. D. BELL

TRC.


CK C. Penet.


AP.


SCALE NONE


DATE 8-29-90 SETNO.


DEPLICATION SHEETNO.







































BY D.R.B. DATE 7/14/82 SUBJECT ROUTE OF FEEDER "RSC" SHEET NO. 5 OF 7 FROM NEW CONTROL BLOG. TO RIVER STATION F F G ##67 . T JEANNETTE G -79 *F 59* 19+51 18+99 3 MONROE FEEDEK "RSC" - *23*+77 T.F. 17+98 23+45 17+74 WILLOW ST. 2-5" DUCTS 67' LONG 22+95 16+86 16 + **4**9 BIRCH M.H. 21+77 15+99 16.5 - 15 +60 20+01 E





	I.D.R.B. DATE Z.IMIB IKO. BY	Z SUBJECT ROUTE OF FEEDER FROM NEW CONTROL BLI	RSC" SHEET NO. 7 OF 7
<u></u>		TO RIVER STATION	
	GEN. OGDEN	Note:	FEEDER MANDON: FOR SPECIFICATIONS REFER TO DING. Nº 1313-F-2
	2-4" / OAK	2-5" PIPE	
:	7	, o'. o'.	37+ 79
I		Grace to District	37+82
	<i>*</i>	THE BRICK MARKET SEC.	36+26
·	:	C Nigo	WITH THE ON EACH SIDE
		M.H. 35+25	OKE PROS
s. ż	•	Figure 63	



































SEWERAGE AND WAITER BOARD OF NEW ORLEANS



ELECTRICAL
ENGINEERING DEPARTMENT





VICINITY MAP

REV. DATE DESCRIPTION BY

SEWERAGE AND WATER BOARD
OF NEW ORLEANS

CONTRACT 6198
1990 - CONSTRUCTION OF FEEDER "RSE"

TITLE SHEET

ETR. D. BELL

TRC.


CK C. Penet.


AP.


SCALE NONE


DATE 8-29-90 SETNO.


DEPLICATION SHEETNO.





































		BILL OF MATERIAL					
TEM		PESCEIPTION	WORK REQUIRED				
		24KV SWITCHGEAD (SEE EQUIP. SPEC.)	MSTALL NEW				
(2)		TRANSFORMER # 1, 7.5 MVA, 24KV/4160V.	INSTALL NEW				
(3)		TRANSFORMER # 2, 7.5 MVA, 24KV/41GOV. (SEE EQUIP. SPEC.)	INSTALL NEW				
4		6600 VOLT, 25 HZ, SWITCH GEAR (SEE EQUIP SPEC.)	INSTALL NEW				
(E)	A CONTROL OF THE CONT	4160VOLT, GOHZ, GWITCHGEAR (GEE EQUIP, GPEC.)	INGTALL NEW				
(b)		CONTROL PANEL, SECTIONS 1-4 (SEE EQUIPMENT SPEC.)	MODIFY & RELOCATE				
(7)		CONTROL PANEL, SECTIONS, 5-9 (SEE E-QUIPMENT SPEC.)	INSTALL NEW				
(B)		25HZ POWER PANEL, 120/240V, 1 P, 3W. 100 A MAIN CIRCUIT BREAKER 50."D" NOO-2-3AB SURFACE MOUNT, WITH NOOP BREAKERS	INSTALL NEW				
(9)		GOHE LIGHTING PANEL, 120/240 V., 1P, 4W., 225A MAIN LUG ONLY SQ. "D" NQO-42-4L SUEFALE MOUNT, WITH NOOPBREAKER	install New				
(10)		60HZ POWER PANEL, 120/2404, 3P, 4W, 400'A. MAIN CIRCUIT BREAKER 69. "D" HCN-2664-B WITH "FA" TYPE BRANCH BREAKERS	iustall new				
(11)		TRANSFORMER # 3, 160 KVA, 4160-120/240V, 3PH, 60HZ DELTA-DELTA, DRY TYPE, INDOORS WITH (2) 21/2% TAPS ABOVE & BELOW, GROUNDED B" PHASE	NEW				
(12).		FIELD CHEOSTAT, FC #1, GO HZ MACHINE	EXISTING - TO REMAIN (CLEAN CONTACTS & CHECK)				
(13)		FIELD CHEOSTAT, FC#1, 25 HZ MACHINE	EXISTING - TO REMAIN (CLEAN CONTACTS & CHECK)				
(14)		Battery Charger, Go He	EXISTING - TO BE RELOCATED				
(B)		BATTERY CHARGER, POWER CONVERSION PRODUCTS (OR EQUAL) MODEL Nº RU-130-12 OPTIONS 1-2-4-5-7-8-11-14, EXCEPT 25 Hz.	NEW				
(16)		BATTERY CHARGER TRANSFER GWITCH, 130VDC 2POLE, DOUBLE THROW NON FUSED 100AMP,	NEW				
		SQUARE" D" CAT. # 82293 OR EQUAL					
			and the second s				

TEM .	DESCRIPTION	WORK REGUIRED
(17)	TRANSFER SWITCH FOR CLOSING CIRCUITS, 130VDC, 2POLE, DOUBLE THROW, WITH 100AMP FUSES IN BOTH PRIMARIES. SQUARE "D" CAT. # 82253F OR EQUAL	NEW
(18)	DISTRIBUTION PANEL, FOR CLOSING CIRCUITS, 130VDC, 100 A, 16, 2W, MAIN LUGS ONLY GE # 240 NAB-8 POLES	NEW
(19)	DC FIELD SWITCHGEAR, 130 VDC	EXISTING - TO BE RELOCATED
20	FIELD RHEOSTAT, FC#2, GOHZ MACHINE	RECONDITION EXISTING EQUIP.
(21)	FIELD RHEOSTAT, FC #2,25HE MACHINE	RECONDITION EXISTING EQUIP
(22)	ROTOR RESISTOR FOR FC#2 STARTING MOTOR	EXISTING - TO
(23)	ROTOR RESISTOR FOR FC#1 STARTING MOTOR	EXISTING - TO REMAIN
(24)	DISTRIBUTION PANEL FOR TRIP CIRCUIT, BOVDC, 100A, 10, 2W, MAIN LUGS ONLY GE 240 NAB- 8 POLES	NEW
(25)	TRANSFER SWITCH FOR TRIP CIRCUITS, 130VPC, 2 POLE, DOUBLE THROW, WITH 100A FUSES IN BOTH PRIMARIES. SQUARE "D" CAT. \$ 52253F OR EQUAL	VEW
(26)	CIRCUIT BREAKER, 480, 3P, GOOA, MOLDED CASE MAGNETIC ONLY, FOR FC#2 STARTING MOTOR 200H.P., SQUARE "D" CAT. # LAL 36600 WITH ENCLOSURE # LAGOOF OR EQUAL	NEW
(27)	TRANSFORMER #T4, 225 KVA, 4160/480V., 3PH, GOHE., DRY TYPE, INDOOR, DELTA-W'E, WITH (2) 21/2% TAPS ABOVE & BELOW SQUARE "D" CAT. # 225T19H OR EQUAL	NEW Control of the Co
(28)	CURRENT METERING TRANSFORMER, 9TY. (3) 400/1 LINE CURRENT, 9TY (1) 100/1 NEUTRAL CURRENT, FOR 6600V, SPH, ZSHE, APPLICATION	FURNISHED BY SWITCHGEAR VENDOR
(29)	LIGHTNING ARRESTORS & SURGE CAPACITORS	EXISTING - YO REMAIN
(30)	METERING CURRENT TRANSFORMERS GTY (3) 800/5 LINE CURRENT GTY. (1) 200/5 NEUTRAL CURRENT	FURLISHED BY SWITCHGEAR VENDOR
(31)	LIGHTHING ARRESTORS & SURGE CAPACITORS	EXISTING - TO
201 1 201 1 201 1 201	CURRENT METERING TRANSFORMERS, 974. (3) 400/5	REMAIN FURNISHED BY
(22)	LINE CURRENT GTT. (1) 100/5 NEUTRAL CURRENT, FOR 4160V., 3PH, 60HZ APPLICATION	gwitchgear Vendor
(33)	CURRENT METERING TRANSFORMERS, 9TY. (3) 1200/5 LINE CURRENT GTY. (1) 200/5 NEUTRAL CURRENT FOR A160V., 3PH, GOHZ APPLICATION	FURNISHED BY SWITCHGEAR VENDOR
(34)	NEUTRAL GROUNDING RESISTOR FOR FC# 2, 25HZ	EXIGTING
(35)	NEUTRAL GROUNDING RESISTOR FOR FC#2, GOHE MACHINE	EXISTING - CHECKOU.
(36)	NEUTRAL GROUNDING RESISTOR FOR FC# 1,25HZ	EXISTING
(37)	HEUTRAL GROUNDING RESISTOR FOR FC# 1, GOHE MACHINE TERMINAL BOX, FC # 1 METERING	EXIGING - CHECKOUT & RECONNECT EXIGING
38	TERMINAL BOX, FC # 2 METERING	EXISTING
39	GROUND CONTACTOR, FC#1 GO HZ (SEE SPEC.)	NEW
40	WITH NEMA-12 ENCLOSURE TO BE THE PROPERTY OF T	NEW*
(41) (42)	GROUND CONTACTOR, FC # 2 GO HZ (SEE SPEC.) WITH NEMA-12 ENCLOSURE TRANSFORMER #5, 30 KVA, DRY TYPE, 6600V/120-240 1P, 25HZ, INDOOR,	NEW
43	RECTIFIER, 12.5 KW., OUTPUT 1304, 100A D.C., INPUT 240 V, 3P LZMARCHE A-28-100-1304	NEW
44>	BATTERY BANK, 130 V DC	RELOCATE EXISTING; FAB NEW RACK
45	LIGHTNING ARRESTORS & SURGE CAPACITORS FOR A1604, 3P, GOHE MOTOR PROTECTION (SEE SPEC.)	NEW
(46)	LIGHTHING ARRESTORS & SURGE CAPACITORS FOR 4100 V., 3P, 60 HE MOTOR PROTECTION (SEE SPEC.) FC #2	NEW
47	GROUND CONTACTOR FC#1 25 Hz (SEESPEC) WITH NEMA-12 ENCLOSURE	
(48)	GROUND CONTACTOR FC #2 25 HZ (SEE SPEC) WITH NEMA-12 ENCLOSURE	
49	METERINGCATIO	EXISTING - TO BE REMOVED
50	FIELD ADJUSTING RHEOSTAT - FC Z EXCITER	EXISTING
(BI)	FIELD ADJUSTING RHEOSTAT - FC EXCITER	EXISTING
52	GOHZ POWER PANEL, 120/240V, 3\$, 4W, 225A MAIN, 4200T	REMOVE EXISTINGE REPLACE W/NEW
53	MOTOR STARTER OIL PUMP # FC-1	EXISTING
54)	MOTOR STARTER OIL PUMP#FC-1	(NOTE-1) EXISTING (NOTE-1)

BILL OF MATERIAL

THE BEST OF (MY OR OUR) KNOWLEDGE AND BELIEF, THEY COMPLY WITH ALL CITY REQUIREMENTS, I AM (SUPERVISING, NOT SUPERVISING) THE WORK

I. EQUIPMENT TO BE REMOUNTED AS NECESSARY TO ACCOMODATE NEW HIGHER FLOOR IN CONTROL ROOM ONLY.

SEWERAGE AND WATER BOARD OF NEW ORLEANS

FREQUENCY CHANGER BLDG. EXPANSION

CARROLLTON STATION EQUIP. LOCATION PLAN & SCHED.

DR. R.M, CK. CRawler

PRELIMINARY

FOR APPROVAL

APPROVED AS NOTED


IL9-84 SW APPROVED FOR CONSTRUCTION 4/15/85 19


WINK DWG. No. 11-020684-P-1201


DRAWING ISSUE


SCALE NONE DATE 7-9-84 SETNO.

DWG. No. 4797- P-5 SHEET NO.










1. ALL EXISTING DRAINAGE STRUCTURES ARE TO BE REMOVED UNLESS NOTED OTHERWISE.

UNLESS NOTED OTHERWISE

3. ALL EXISTING STREET LIGHTS SHALL REMAIN UNLESS NOTED OTHERWISE.


4. EXISTING DRAIN LINES THAT CANNOT BE REMOVED SHALL BE FILLED WITH SAND AND PLUGGED BY THE CONTRACTOR.


2. THE ONLY ACCEPTABLE ALTERNATE TO S.D.P. IS R.C.P. (REINFORCED CONCRETE PIPE)





STRN	O. DESCRIPTION	INV	ERTS
		UPPER	LOWE
	EASTBOUND	•	•
236	STA. 36+13 REQD. 36"x 308' SDP W/1 36"x 36"x 15" WYE	13.03	13.34
237	STA. 36+40 REQD. SDOCB		
238	STA. 36+38.5 REQD. 15"x5' SDP	15.59	14.09
239	STA. 34+59.5 REQD. STD. M.H. NO. 3	*. }	
240	STA. 34+61 REQD. 18"x 5' SDP	15.00	14.98
241	STA. 34+62.5 REQD. DVCB		
242	STA. 34+44.5 REQD. 36"x 31' SDP	13.03	13.00
243	STA. 34+01 REQD. VCB		
244	STA. 34+02.5 REQD. 15"x 5' SDP	15.17	15.12
246	STA. 34+16.5 REQD. 15"x 24' SDP W/1 15"x 15"x 15" WYE	15.12	15.00
248	EXIST. 42"x 46" SDP		
	WESTBOUND		
334	STA. 236+20 REQD. 30"x 304' SDP W/1 30"x 30"x 15" WYE	13.79	13.48
335	STA. 236+48 REQD. VCB		
336	STA. 236+46.5 REQD. 15"x 5' SDP	15.78	14.28
337	STA. 234+71 REQD. DVCB		
338	STA. 234+69.5 REQD. 15"x 5' SDP	16.02	16.00
339	STA. 234+68 REQD. STD. M.H. NO. 2		
340	STA. 234+51 REQD. 30"x 34" SDP	13.48	13.45
341	STA. 234+05 REQD. VCB		
342	STA. 234+06.5 REQD. 15"x 5' SDP	16.18	16.13
344	STA. 234+21 REQD. 15"x 26' SDP W/1 15"x 15"x 15" WYE	16.13	16.00
345	STA. 234+34 REQD. STD. M.H. NO. 2		


BEGIN WESTBOUND & P.O.C. STA. 233+99.83 = P.O.T. STA. 134+00.00-46.31' RT. EXIST. S&WB FOR 404 BEGIN EASTBOUND & P.O.C. STA. 33+99.61 = P.O.T. STA. 134+00.00-39.09" RT. SURVEY LINE REQ'D. ELEC. DUCTBANK ------REQ'D. ELEC. M.H. #5B SEE NOTE #3 SEE NOTES 1 & 2 SEE NOTES 1 & 2--f-024' E.B. & 0000 0000 Conc. EXIST. & REQ'D. R/W 0000 CONTRACTOR TO FURNISH AND INSTALL TWELVE (12)-6" SCHEDULE 40 PVC CONDUITS, ENCASED IN REINFORCED CONCRETE.
 TOP OF DUCTBANK SHALL BE THREE (3) FEET BELOW STREET GRADE, UNLESS OTHERWISE SPECIFIED. SEE PROFILE. 1 CURVE DATA ©CURVE DATA CONTRACTOR TO FURNISH AND INSTALL NEW MANHOLES AS PER S&WB DWG No. 1000-P5B. P.I. = 234+34.93 = P.O.T. 134+34.90-50.10' LT. SURVEY LINE Δ =03'37'22.9" RT. D=1'45' P.I. = 34+60.47 = P.O.T 134+60.58-33.15' RT. SURVEY LINE $\Delta = 07'48'13.1''$ RT. D=3'45" T = 103.55'T = 104.21' L = 208.10' R = 1527.89' e = 3.55' L = 207.03' R = 3274.04' e = 1.64P.C.=233+31.38 = P.O.T. 133+31.78-41.03' LT. SURVEY LINE P.T.=235+38.41 = P.O.T. 135+38.42-52.63' LT. SURVEY LINE P.C.=33+56.26 = P.O.T. 133+56.77-42.27' RT. SURVEY LINE P.T.=35+64.36 = P.O.T. 135+64.66-38.21' RT. SURVEY LINE

































































SEWERAGE &WATER BOARD OF NEW ORLEANS

ELECTRICAL ENGINEERING DEPARTMENT

CONTACT No. 6248

INSTALLATION OF TWO 60 - HERTZ FEEDERS FROM THE CARROLLTON WATER PLANT TO DRAINAGE PUMPING STATION #1





			
REV.	DATE	DESCRIPTION	


ISTALLATION OF TWO 60—HERTZ FEEDERS
FROM THE CARROLLTON WATER PLANT
TO DRAINAGE PUMPING STATION 1


CONTRACT 6248


DR. THUYAN NGUYEN		?	
LAST EDIT JULY 12, 2013	Mough	Derke	
CK.	GENERAL SI	IPERINTENDENT	
AFO S SUDAN	DWG. No.	5058 -	- P0
SCALE AS SHOWN	SET NO	SHEET NO	1 OF 30

































































(A); /		Í.	DUCTBANK				7m, y 2, m, mm m
B Coliborne Substation FCB=A10 PMH-OO4A EX-5"	TAG	C.	CIRCUIT	FROM	7.27	SIZE	DUCTBANK ARRANGEMENT
C EMPTY FCB-A11 PMH-O04A EX-5" d EMPTY FCB-A12 PMH-004A EX-5" f EMPTY FCB-A12 PMH-004A EX-5" f EMPTY FCB-A12 PMH-004A EX-5" g PPTES 3-1000MCM(6kV), 4/0 € (600V) FCB-A13 PMH-004A EX-5" i 80 PTE 20 Power House #3 FCB-A15 PMH-004A EX-5" j 60 Hz Power House #3 FCB-A15 PMH-004A EX-5" d 0 Hz FOwer House #3 FCB-A15 PMH-004A EX-5" au 60 Hz Sycamore Substation FCB-A4 PMH-004A EX-5" ec 80 Hz Sycamore Substation FCB-A4 PMH-004A EX-5" ec 80 Hz Sycamore Substation FCB-A5 PMH-004A EX-5" dd Boller Room FCB-A5 PMH-004A EX-5" ff Hamilton Substation FCB-A6 PMH-004A EX-5" ff Boller Room FCB-A6 PMH-004A EX-5"		a	Claiborne Substation	FCB-A10	PMH-004A		
d EMPTY FOB-A11 PMH-004A EX-5" e PFIE: 3-1000MCM(8KV), 4/0 G (600V) FOB-A12 PMH-004A EX-5" f EMPTY EMPTY PMH-004A EX-5" g PFIE: 3-1000MCM(8KV), 4/0 G (600V) FOB-A13 PMH-004A EX-5" h Carrollton EX. 8/2 FOB-A13 PMH-004A EX-5" i 60 Hz Power House #3 FOB-A15 PMH-004A EX-5" j 60 Hz Power House #3 FOB-A15 PMH-004A EX-5" k 80 Hz Power House #3 FOB-A15 PMH-004A EX-5" k 80 Hz Power House #3 FOB-A15 PMH-004A EX-5" k 80 Hz Power House #3 FOB-A15 PMH-004A EX-5" k 80 Hz Power House #3 FOB-A15 PMH-004A EX-5" k 80 Hz Power House #3 FOB-A15 PMH-004A EX-5" k 80 Hz Power House #3 FOB-A15 PMH-004A EX-5" d 80 Hz Power House #3 FOB-A15 PMH-004A EX-5" d 60 Hz Power House #3 FOB-A15 PMH-004A EX-5" d 80 Hz Power House #3 FOB-A15 PMH-004A EX-5" d 80 Hz Power House #3 FOB-A15 PMH-004A EX-5" d 80 Hz Power House #3 FOB-A15 PMH-004A EX-5" d 80 Hz Power House #3 FOB-A15 PMH-004A EX-5" d 80 Hz Power House #3 FOB-A15 PMH-004A EX-5" d 80 Hz Power House #3 FOB-A15 PMH-004A EX-5" d 80 Hz Power House #3 FOB-A15 PMH-004A EX-5" d 80 Hz PWH-004A EX-5" FOB-A24 PMH-004A EX-5"		b	Claiborne Substation	FCB-A10	PMH-004A		
PFIF. 3-1000MCM(BKV), 4/0 G (600V) FOB-A12 PMH-004A EX-5" F EMPTY FOE-A13 PMH-004A EX-5" D FFIG. 3-1000MCM(BKV), 4/0 G (600V) FOE-A13 PMH-004A EX-5" D FFIG. 3-1000MCM(BKV), 4/0 G (600V) FOE-A13 PMH-004A EX-5" D FFIG. 3-1000MCM(BKV), 4/0 G (600V) FOE-A13 PMH-004A EX-5" D FFIG. 3-1000MCM(BKV), 4/0 G (600V) FOE-A15 PMH-004A EX-5" D FFIG. 3-1000MCM(BKV), 4/0 G (600V) FOE-004A EX-5" D FFIG. 3-1000MCM(BKV), 4/0 G (600V) FOE-004A FMH-004A EX-5" D FFIG. 3-1000MCM(BKV), 4/0 G (600V) FOE-004A FMH-004A EX-5" D FFIG. 3-1000MCM(BKV), 4/0 G (600V) FMH-004A EX-5" D FFIG. 3-1000MCM(BKV), 4/0 G (600V) FMH-004B EX-5" D FFIG. 3-1000MCM(BKV), 4/0 G (600V) FMH-004C EM-004C EX-5" D FFIG. 3-1000MCM(BKV), 4/0 G (600V) FMH-004C EM-004C EX-5" D FFIG. 3-1000MCM(BKV), 4/0 G (600V) FMH-004C E		С	EMPTY	FCB-A11	PMH-004A	EX-5"	
F		d	EMPTY	FCB-A11	PMH-004A	EX-5"	
PF16: 3-1000MCM(RKY), 4/0 G (600Y) FCB-A13 PMH-004A EX-5" 1 60 Ht 2 Power House #3 FCB-A15 PMH-004A EX-5" 1 60 Ht 2 Power House #3 FCB-A15 PMH-004A EX-5" 1 60 Ht 2 Power House #3 FCB-A15 PMH-004A EX-5" 1 60 Ht 2 Power House #3 FCB-A15 PMH-004A EX-5" 2 60 Ht 2 Power House #3 FCB-A15 PMH-004A EX-5" 3 60 Ht 2 Sycomore Substation FCB-A1 PMH-004A EX-5" 4 60 Ht 2 Sycomore Substation FCB-A1 PMH-004A EX-5" 5 60 Ht 2 Sycomore Substation FCB-A1 PMH-004A EX-5" 6 60 Ht 2 Sycomore Substation FCB-A2 PMH-004A EX-5" 6 60 Ht 2 Sycomore Substation FCB-A3 PMH-004A EX-5" 6 60 Ht 2 Sycomore Substation FCB-A5 PMH-004A EX-5" 6 60 Ht 2 Sycomore Substation FCB-A5 PMH-004A EX-5" 7 60 Ht 2 Sycomore Substation FCB-A6 PMH-004A EX-5" 8 Hemilton Substation FCB-A6 PMH-004A EX-5" 9 60 Ht 2 Sycomore Substation FCB-A6 PMH-004A EX-5" 10 60 Ht 2 Sycomore Substation FCB-A4 PMH-004A EX-5" 10 60 Ht 2 Sycomore Substation FCB-A4 PMH-004A EX-5" 10 60 Ht 2 Sycomore Substation FCB-A4 PMH-004B EX-5" 10 60 Ht 2 Sycomore Substation FCB-A4 PMH-004B EX-5" 10 60 Ht 2 Sycomore Substation FCB-A4 PMH-004B EX-5" 10 60 Ht 2 Sycomore Substation FCB-A4 PMH-004B EX-5" 10 60 Ht 2 Sycomore Substation FCB-A4 PMH-004B EX-5" 10 60 Ht 2 Sycomore Substation FCB-A4 PMH-004B EX-5" 10 60 Ht 2 Sycomore Substation FCB-A4 PMH-004B EX-5" 10 60 Ht 2 Sycomore Substation FCB-A4 PMH-004B EX-5" 10 60 Ht 2 Sycomore Substation FCB-A4 PMH-004B EX-5" 10 60 Ht 2 Sycomore Substation FCB-A4 PMH-004B EX-5" 10 60 Ht 2 Sycomore Substation FCB-A4 PMH-004B EX-5" 10 60 Ht 2 Sycomore Substation FCB-A4 PMH-004B EX-5" 10 60 Ht 2 Sycomore Substation FCB-A4 PMH-004B EX-5" 10 60 Ht 2 Sycomore Substation FCB-A4 PMH-004B EX-5" 10 60 Ht 2 Sycomore Substation FCB-A4 PMH-004B EX-5" 10		е	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	FCB-A12	PMH-004A	EX-5"	÷
BFIGS 3-1000MCM(8KY), 4/0 € (6000Y) FGB-A13 PMH-004A EX-5" h Carroliton FC, #2 FCB-A15 PMH-004A EX-5" i 60 Hz Power House #3 FCB-A15 PMH-004A EX-5" j 60 Hz Power House #3 FCB-A15 PMH-004A EX-5" k 60 Hz Power House #3 FCB-A15 PMH-004A EX-5" k 60 Hz Power House #3 FCB-A15 PMH-004A EX-5" k 60 Hz Power House #3 FCB-A15 PMH-004A EX-5" k 60 Hz Power House #3 FCB-A15 PMH-004A EX-5" k 60 Hz Power House #3 FCB-A15 PMH-004A EX-5" k 60 Hz Power House #3 FCB-A15 PMH-004A EX-5" k 60 Hz Power House #3 FCB-A15 PMH-004A EX-5" k 60 Hz Power House #3 FCB-A15 PMH-004A EX-5" k 60 Hz Power Substation FCB-A4 PMH-004A EX-5" c 60 Hz Power Substation FCB-A4 PMH-004A EX-5" d Boiler Room FCB-A5 PMH-004A EX-5" f Hamilton Substation FCB-A6 PMH-004A EX-5" f Hamilton Substation FCB-A6 PMH-004A EX-5" ii 60 Hz Power Substation FCB-A6 PMH-004A EX-5" ii 60 Hz Power Substation FCB-A4 PMH-004B EX-5" ii 60 Hz Power Substation FCB-A4 PM		f	EMPTY	FCB-A12	PMH-004A		TVDE 1
1		g	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	FCB-A13	PMH-004A	EX-5"	IIE I
j		h	Carrollton F.C. #2	FCB-A13	PMH-004A	EX-5"	
R		•	60 Hz Power House #3	FCB-A15	PMH-004A	EX-5"	
1		j	60 Hz Power House #3	FCB-A15	PMH-004A	EX-5"	
1		k	60 Hz Power House #3			EX-5"	·
Ba	0		60 Hz Power House #3				· v
bb 60 Hz Sycamore Substation FCB=A4 PMH-004A EX-5" cc 60 Hz Sycamore Substation FCB=A5 PMH-004A EX-5" dd 80iler Room FCB=A5 PMH-004A EX-5" ee Boiler Room FCB=A5 PMH-004A EX-5" FCB=A6 PMH-004A EX-5" FMH-004A EX-5" FMH-004A EX-5" FMH-004A EX-5" FMH-004B EX-5" FMH-004C EX-5" FMH-004B EX-5" FMH-004B EX-5" FMH-004C EX-5"		aa			·	· · · · · · · · · · · · · · · · · · ·	
CC 60 Hz Sycamore Substation FCB=A4 PMH-004A EX-5" Ad Boiler Room FCB=A5 PMH-004A EX-5" FCB=A6 PMH-004A EX-5" FCB=A6 PMH-004A EX-5" FCB=A6 PMH-004A EX-5" FCB=A6 PMH-004A EX-5" FCB=A4 PMH-004A EX-5" FCB=					 		
dd Boiler Room FCB-A5 PMH-004A EX-5" ee Boiler Room FCB-A5 PMH-004A EX-5" ff Hamilton Substation FCB-A6 PMH-004A EX-5" ff Hamilton Substation FCB-A6 PMH-004A EX-5" fh Hamilton Substation FCB-A6 PMH-004A EX-5" ii 60 Hz Sycamore Substation FCB-A4 PMH-004A EX-5" iii 60 Hz Sycamore Substation FCB-A4 PMH-004B EX-5" iii FPFIG: 3-1000MCM(8KV), 4/0 G (600V) FMH-004B PMH-004C EX-5" iii FMFIY PMH-004C PMH-005A EX-5" iii FMFIY PMH-004C PMH-005A EX-5" iii FMFIY PMH-004C PMH-005A EX-5" iii EMFIY PMH-004C PMH-005A EX-5" iii EMFIY PMH-004C PMH-005A EX-5" iii EMFIY PMH-							
ec Boiler Room FCB-A5 PMH-004A EX-5" FT Hamilton Substation FCB-A6 PMH-004A EX-5" PMH-004A PMH-004B EX-5" PMH-004B PMH-004B EX-5" PMH-004B EX-5" PMH-004B PMH-004C EX-5" EM-5" PMH-004C EX-5" EM-5" PMH-004C EX-5" EM-5" PMH-004C EX-5" EM-5" PMH-004C PMH-005A	20	···			 	 	
ff Hamilton Substation FCB-A6 PMH-004A EX-5" gg Hamilton Substation FCB-A6 PMH-004A EX-5" ii 60 Hz Sycamore Substation FCB-A4 PMH-004A EX-5" ii 60 Hz Sycamore Substation FCB-A4 PMH-004A EX-5" ji 60 Hz Sycamore Substation FCB-A4 PMH-004A EX-5" a EMPTY PMH-004A PMH-004B EX-5" b EMPTY PMH-004A PMH-004B EX-5" c EMPTY PMH-004A PMH-004B EX-5" d EMPTY PMH-004A PMH-004B EX-5" f PFIF: 3-1000MCM(8kV), 4/0 G (600V) PMH-004A PMH-004B EX-5" g EMPTY PMH-004B PMH-004C EX-5" h PFIG: 3-1000MCM(8kV), 4/0 G (600V) PMH-004B PMH-004C EX-5" a EMPTY PMH-004B PMH-004C EX-5" d EMPTY PMH-004B PMH-004C EX-5"					 	· · · · · · · · · · · · · · · · · · ·	
Sg							TVDE 14
hh 60 Hz Sycamore Substation FCB-A4 PMH-004A EX-5"				<u> </u>			I TIPE IA
13							
jj 60 Hz Sycamore Substation FCB-A4 PMH-004A EX-5" a EMPTY PMH-004A PMH-004B EX-5" b EMPTY PMH-004A PMH-004B EX-5" c EMPTY PMH-004A PMH-004B EX-5" d EMPTY PMH-004A PMH-004B EX-5" d EMPTY PMH-004A PMH-004B EX-5" f PF1F: 3-1000MCM(8KV), 4/0 G (600V) FCB-004A PMH-004B EX-5" g EMPTY PMH-004A PMH-004B EX-5" h PF1G: 3-1000MCM(6KV), 4/0 G (600V) PMH-004A PMH-004B EX-5" a EMPTY PMH-004A PMH-004C EX-5" b EMPTY PMH-004B PMH-004C EX-5" d EMPTY PMH-004B PMH-004C EX-5" g EMPTY PMH-004B PMH-004C EX-5" d EMPTY PMH-004B PMH-004C EX-5" d EMPTY PMH-004B PMH-004C EX-5" d EMPTY PMH-004C PMH-005A					 	<u> </u>	
A		<u> </u>		• • • • • • • • • • • • • • • • • • • •	<u> </u>	- 	
B EMPTY		JJ	60 Hz Sycamore Substation	FCB-A4	PMH-004A	EX-5"	
C EMPTY		a	EMPTY	PMH-004A	PMH-004B	EX-5"	
1&2 d		b	EMPTY	PMH-004A	PMH-004B	EX-5"	
1&2 d EMPTY PMH-004A PMH-004B EX-5" e EMPTY PMH-004A PMH-004B EX-5" f PF1F: 3-1000MCM(8kV), 4/0 G (600V) PCB-004A PMH-004B EX-5" g EMPTY PMH-004A PMH-004B EX-5" h PF1G: 3-1000MCM(8kV), 4/0 G (600V) PMH-004A PMH-004B EX-5" b EMPTY PMH-004B PMH-004C EX-5" c EMPTY PMH-004B PMH-004C EX-5" d EMPTY PMH-004B PMH-004C EX-5" d EMPTY PMH-004B PMH-004C EX-5" d EMPTY PMH-004B PMH-004C EX-5" g EMPTY PMH-004B PMH-004C EX-5" h PF16: 3-1000MCM(8kV), 4/0 G (600V) PMH-004B PMH-004C EX-5" a EMPTY PMH-004C PMH-005A EX-5" b EMPTY PMH-004C PMH-005A EX-5" c		· c	EMPTY	PMH-004A	PMH-004B	EX-5"	
1&2 c		d	EMPTY	<u> </u>			
f PF1F: 3-1000MCM(8kV), 4/0 G (600V) FCB-004A PMH-004B EX-5" g EMPTY PMH-004A PMH-004B EX-5" h PF1G: 3-1000MCM(8kV), 4/0 G (600V) PMH-004B PMH-004B EX-5" a EMPTY PMH-004B PMH-004C EX-5" b EMPTY PMH-004B PMH-004C EX-5" c EMPTY PMH-004B PMH-004C EX-5" d EMPTY PMH-004B PMH-004C EX-5" d EMPTY PMH-004B PMH-004C EX-5" f PF1F: 3-1000MCM(8kV), 4/0 G (600V) PMH-004B PMH-004C EX-5" g EMPTY PMH-004B PMH-004C EX-5" h PF1G: 3-1000MCM(8kV), 4/0 G (600V) PMH-004B PMH-004C EX-5" a EMPTY PMH-004C PMH-005A EX-5" c EMPTY PMH-004C PMH-005A EX-5" d EMPTY PMH-004C PMH-005A EX-5" e </td <td>1&2</td> <td>e</td> <td></td> <td></td> <td></td> <td></td> <td>TYPE 6</td>	1&2	e					TYPE 6
B	сь 70	f		 	· · · · · · · · · · · · · · · · · · ·		
N		Q			1	 	·
b EMPTY PMH-004B PMH-004C EX-5" c EMPTY PMH-004B PMH-004C EX-5" d EMPTY PMH-004B PMH-004C EX-5" e CKT-216 PMH-004B PMH-004C EX-5" f PF1F: 3-1000MCM(8KV), 4/0 G (600V) PMH-004B PMH-004C EX-5" g EMPTY PMH-004B PMH-004C EX-5" h PF1G: 3-1000MCM(8KV), 4/0 G (600V) PMH-004B PMH-004C EX-5" a EMPTY PMH-004C PMH-005A EX-5" b EMPTY PMH-004C PMH-005A EX-5" c EMPTY PMH-004C PMH-005A EX-5" d EMPTY PMH-004C PMH-005A EX-5" e EMPTY PMH-004C PMH-005A EX-5" g EMPTY PMH-004C PMH-005A EX-5" h EMPTY PMH-004C PMH-005A EX-5" j EMPTY PMH-004C				<u> </u>		1	·
b EMPTY PMH-004B PMH-004C EX-5" c EMPTY PMH-004B PMH-004C EX-5" d EMPTY PMH-004B PMH-004C EX-5" e CKT-216 PMH-004B PMH-004C EX-5" f PF1F: 3-1000MCM(8KV), 4/0 G (600V) PMH-004B PMH-004C EX-5" g EMPTY PMH-004B PMH-004C EX-5" h PF1G: 3-1000MCM(8KV), 4/0 G (600V) PMH-004B PMH-004C EX-5" a EMPTY PMH-004C PMH-005A EX-5" b EMPTY PMH-004C PMH-005A EX-5" c EMPTY PMH-004C PMH-005A EX-5" d EMPTY PMH-004C PMH-005A EX-5" f PF1F: 3-1000MCM(8KV), 4/0 G (600V) PMH-004C PMH-005A EX-5" g EMPTY PMH-004C PMH-005A EX-5" j EMPTY PMH-004C PMH-005A EX-5" k CKT-217 <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td>							
c EMPTY PMH-004B PMH-004C EX-5" d EMPTY PMH-004B PMH-004C EX-5" e CKT-216 PMH-004B PMH-004C EX-5" f PF1F: 3-1000MCM(BKV), 4/0 G (600V) PMH-004B PMH-004C EX-5" g EMPTY PMH-004B PMH-004C EX-5" h PF1G: 3-1000MCM(BKV), 4/0 G (600V) PMH-004B PMH-004C EX-5" a EMPTY PMH-004C PMH-005A EX-5" b EMPTY PMH-004C PMH-005A EX-5" c EMPTY PMH-004C PMH-005A EX-5" d EMPTY PMH-004C PMH-005A EX-5" g EMPTY PMH-004C PMH-005A EX-5" g EMPTY PMH-004C PMH-005A EX-5" j EMPTY PMH-004C PMH-005A EX-5" j EMPTY PMH-004C PMH-005A EX-5" k CKT-217 PMH-004C		a					
d EMPTY		<u>b</u>		PMH-004B	PMH-004C		
3 e CKT-216 PMH-004B PMH-004C EX-5" f PF1F: 3-1000MCM(8KV), 4/0 G (600V) PMH-004B PMH-004C EX-5" g EMPTY PMH-004B PMH-004C EX-5" h PF1G: 3-1000MCM(8KV), 4/0 G (600V) PMH-004B PMH-004C EX-5" a EMPTY PMH-004C PMH-005A EX-5" b EMPTY PMH-004C PMH-005A EX-5" c EMPTY PMH-004C PMH-005A EX-5" d EMPTY PMH-004C PMH-005A EX-5" e EMPTY PMH-004C PMH-005A EX-5" g EMPTY PMH-004C PMH-005A EX-5" g EMPTY PMH-004C PMH-005A EX-5" h EMPTY PMH-004C PMH-005A EX-5" j EMPTY PMH-004C PMH-005A EX-5" k CKT-217 PMH-004C PMH-005A EX-5" m PF16: 3-1000MCM(8KV		<u> </u>	EMPTY	PMH-004B	PMH-004C	-	
f PF1F: 3-1000MCM(8kV), 4/0 G (600V) PMH-004B PMH-004C EX-5" g EMPTY PMH-004B PMH-004C EX-5" h PF1G: 3-1000MCM(8kV), 4/0 G (600V) PMH-004B PMH-004C EX-5" EX-5" a EMPTY PMH-004C PMH-005A EX-5" b EMPTY PMH-004C PMH-005A EX-5" c EMPTY PMH-004C PMH-005A EX-5" d EMPTY PMH-004C PMH-005A EX-5" e EMPTY PMH-004C PMH-005A EX-5" f PF1F: 3-1000MCM(8kV), 4/0 G (600V) PMH-004C PMH-005A EX-5" g EMPTY PMH-004C PMH-005A EX-5" j EMPTY PMH-004C PMH-005A EX-5" i EMPTY PMH-004C PMH-005A EX-5" j EMPTY PMH-004C PMH-005A EX-5" j EMPTY PMH-004C PMH-005A EX-5" i EMPTY PMH-004C PMH-005A EX-5" j EMPTY PMH-004C PMH-005A EX-5" l EMPTY PMH-004C PMH-005A EX-5"		d	EMPTY	PMH-004B	PMH-004C	EX-5"	·
## BENTY PMH-004B PMH-004C EX-5"	3	e		PMH-004B	PMH-004C		TYPE 6
h PF1G: 3-1000MCM(8KV), 4/0 G (600V) PMH-004B PMH-004C EX-5" a EMPTY PMH-004C PMH-005A EX-5" b EMPTY PMH-004C PMH-005A EX-5" c EMPTY PMH-004C PMH-005A EX-5" d EMPTY PMH-004C PMH-005A EX-5" e EMPTY PMH-004C PMH-005A EX-5" f PF1F: 3-1000MCM(8KV), 4/0 G (600V) PMH-004C PMH-005A EX-5" g EMPTY PMH-004C PMH-005A EX-5" h EMPTY PMH-004C PMH-005A EX-5" j EMPTY PMH-004C PMH-005A EX-5" j EMPTY PMH-004C PMH-005A EX-5" k CKT-217 PMH-004C PMH-005A EX-5" l EMPTY PMH-004C PMH-005A EX-5" m PF1G: 3-1000MCM(8KV), 4/0 G (600V) PMH-004C PMH-005A EX-5" m PF1G: 3-1000MCM(8KV), 4/0 G (600V) PMH-004C PMH-005A EX-5" n EMPTY PMH-004C PMH-005A EX-5" m PF1G: 3-1000MCM(8KV), 4/0 G (600V) PMH-004C PMH-005A EX-5" n EMPTY PMH-004C PMH-005A EX-5"		f	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-004B	PMH-004C	EX-5"	
## BENETY ## BEN		g	EMPTY	PMH-004B	PMH-004C	EX-5"	
a EMPTY PMH-004C PMH-005A EX-5" b EMPTY PMH-004C PMH-005A EX-5" c EMPTY PMH-004C PMH-005A EX-5" d EMPTY PMH-004C PMH-005A EX-5" e EMPTY PMH-004C PMH-005A EX-5" f PF1F: 3-1000MCM(8KV), 4/0 G (600V) PMH-004C PMH-005A EX-5" g EMPTY PMH-004C PMH-005A EX-5" h EMPTY PMH-004C PMH-005A EX-5" j EMPTY PMH-004C PMH-005A EX-5" j EMPTY PMH-004C PMH-005A EX-5" k CKT-217 PMH-004C PMH-005A EX-5" l EMPTY PMH-004C PMH-005A EX-5" m PF1G: 3-1000MCM(8KV), 4/0 G (600V) PMH-004C PMH-005A EX-5" n EMPTY PMH-004C PMH-005A EX-5"		h	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-004B	PMH-004C	EX-5"	
b EMPTY PMH-004C PMH-005A EX-5" c EMPTY PMH-004C PMH-005A EX-5" d EMPTY PMH-004C PMH-005A EX-5" e EMPTY PMH-004C PMH-005A EX-5" f PF1F: 3-1000MCM(8KV), 4/0 G (600V) PMH-004C PMH-005A EX-5" g EMPTY PMH-004C PMH-005A EX-5" h EMPTY PMH-004C PMH-005A EX-5" i EMPTY PMH-004C PMH-005A EX-5" j EMPTY PMH-004C PMH-005A EX-5" k CKT-217 PMH-004C PMH-005A EX-5" l EMPTY PMH-004C PMH-005A EX-5" m PF1G: 3-1000MCM(8KV), 4/0 G (600V) PMH-004C PMH-005A EX-5" n EMPTY PMH-004C PMH-005A EX-5" pMH-004C PMH-005A EX-5" m PF1G: 3-1000MCM(8KV), 4/0 G (600V) PMH-004C PMH-005A EX-5" pMH-004C PMH-005A EX-5" pMH-004C PMH-005A EX-5"							
C EMPTY	ş	a	EMPTY	PMH-004C	PMH-005A	EX-5"	
d EMPTY PMH-004C PMH-005A EX-5" e EMPTY PMH-004C PMH-005A EX-5" f PF1F: 3-1000MCM(8KV), 4/0 G (600V) PMH-004C PMH-005A EX-5" g EMPTY PMH-004C PMH-005A EX-5" h EMPTY PMH-004C PMH-005A EX-5" j EMPTY PMH-004C PMH-005A EX-5" j EMPTY PMH-004C PMH-005A EX-5" k CKT-217 PMH-004C PMH-005A EX-5" l EMPTY PMH-004C PMH-005A EX-5" m PF1G: 3-1000MCM(8KV), 4/0 G (600V) PMH-004C PMH-005A EX-5" n EMPTY PMH-004C PMH-005A EX-5"		b	EMPTY	PMH-004C	PMH-005A	EX-5"	
e EMPTY f PF1F: 3-1000MCM(8KV), 4/0 G (600V) PMH-004C PMH-005A EX-5" g EMPTY PMH-004C PMH-005A EX-5" h EMPTY PMH-004C PMH-005A EX-5" PMH-005A EX-5" PMH-005A EX-5" PMH-005A EX-5" PMH-005A EX-5" PMH-005A EX-5" i EMPTY PMH-004C PMH-005A EX-5" FMH-005A EX-5" PMH-005A EX-5"		c	EMPTY	PMH-004C	PMH-005A	EX-5"	
f PF1F: 3-1000MCM(8KV), 4/0 G (600V) PMH-004C PMH-005A EX-5" g EMPTY PMH-004C PMH-005A EX-5" h EMPTY PMH-004C PMH-005A EX-5" i EMPTY PMH-004C PMH-005A EX-5" j EMPTY PMH-004C PMH-005A EX-5" k CKT-217 PMH-004C PMH-005A EX-5" l EMPTY PMH-004C PMH-005A EX-5" m PF1G: 3-1000MCM(8KV), 4/0 G (600V) PMH-004C PMH-005A EX-5" n EMPTY PMH-004C PMH-005A EX-5"		d	EMPTY	PMH-004C	PMH-005A	EX-5"	
9 EMPTY PMH-004C PMH-005A EX-5" h EMPTY PMH-004C PMH-005A EX-5" i EMPTY PMH-004C PMH-005A EX-5" j EMPTY PMH-004C PMH-005A EX-5" k CKT-217 PMH-004C PMH-005A EX-5" l EMPTY PMH-004C PMH-005A EX-5" m PF1G: 3-1000MCM(8KV), 4/0 G (600V) PMH-004C PMH-005A EX-5" n EMPTY PMH-004C PMH-005A EX-5" pMH-004C PMH-005A EX-5" pMH-004C PMH-005A EX-5"		e	EMPTY	PMH-004C	PMH-005A	EX-5"	
9 EMPTY PMH-004C PMH-005A EX-5" h EMPTY PMH-004C PMH-005A EX-5" i EMPTY PMH-004C PMH-005A EX-5" j EMPTY PMH-004C PMH-005A EX-5" k CKT-217 PMH-004C PMH-005A EX-5" l EMPTY PMH-004C PMH-005A EX-5" m PF1G: 3-1000MCM(8KV), 4/0 G (600V) PMH-004C PMH-005A EX-5" n EMPTY PMH-004C PMH-005A EX-5" pMH-004C PMH-005A EX-5" PMH-004C PMH-005A EX-5"		f	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-004C	PMH-005A	EX-5"	4.4
4 h EMPTY PMH-004C PMH-005A EX-5" i EMPTY PMH-004C PMH-005A EX-5" j EMPTY PMH-004C PMH-005A EX-5" k CKT-217 PMH-004C PMH-005A EX-5" l EMPTY PMH-004C PMH-005A EX-5" m PF1G: 3-1000MCM(8KV), 4/0 G (600V) PMH-004C PMH-005A EX-5" n EMPTY PMH-004C PMH-005A EX-5"		g		PMH-004C			
i EMPTY PMH-004C PMH-005A EX-5" j EMPTY PMH-004C PMH-005A EX-5" k CKT-217 PMH-004C PMH-005A EX-5" l EMPTY PMH-004C PMH-005A EX-5" m PF1G: 3-1000MCM(8KV), 4/0 G (600V) PMH-004C PMH-005A EX-5" n EMPTY PMH-004C PMH-005A EX-5"	1	h	EMPTY	PMH-004C			T/DE /
j EMPTY PMH-004C PMH-005A EX-5" k CKT-217 PMH-004C PMH-005A EX-5" l EMPTY PMH-004C PMH-005A EX-5" m PF1G: 3-1000MCM(8KV), 4/0 G (600V) PMH-004C PMH-005A EX-5" n EMPTY PMH-004C PMH-005A EX-5"	4			 			IYPE 4
k CKT-217 PMH-004C PMH-005A EX-5" 1 EMPTY PMH-004C PMH-005A EX-5" m PF1G: 3-1000MCM(8KV), 4/0 G (600V) PMH-004C PMH-005A EX-5" n EMPTY PMH-004C PMH-005A EX-5"		j		1.		1	
1 EMPTY PMH-004C PMH-005A EX-5" m PF1G: 3-1000MCM(8KV), 4/0 G (600V) PMH-004C PMH-005A EX-5" n EMPTY PMH-004C PMH-005A EX-5"		k					
m PF1G: 3-1000MCM(8KV), 4/0 G (600V) PMH-004C PMH-005A EX-5" n EMPTY PMH-004C PMH-005A EX-5"		1	· · · · · · · · · · · · · · · · · · ·	1			
n EMPTY PMH-004C PMH-005A EX-5"		1		<u> </u>			
						-	
PMH-004C PMH-005A EX-5	چ		**************************************				
		0	UNI-310	PMH-UU4C	PMH-005A 	LX-5	

		DUCTBANK	SCHE	EDULE		
TAG	<i>C.</i>	CIRCUIT	FRIM	7.27	SIZE	DUCTBANK ARRANGEMENT
	a	EMPTY	PMH-005A	PMH-005B	EX-5"	
	b	EMPTY	PMH-005A	PMH-005B	EX-5"	
	c	EMPTY	PMH-005A	PMH-005B	EX-5"	
	d	EMPTY	PMH-005A	PMH-005B	EX-5"	.
	e	EMPTY	PMH-005A	PMH-005B	EX-5"	
	f	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-005A	PMH-005B	EX-5"	
			PMH-005A	PMH-005B	EX-5"	_
	g	EMPTY	PMH-005A	PMH-005B	EX-5"	-
5	h ;	EMPTY	PMH-005A	PMH-005B	EX-5"	TYPE-4
	1	EMPTY	PMH-005A	PMH-005B	EX-5"	
	1_	EMPTY CKT-217	 		EX-5"	· -
	k		PMH-005A	PMH-005B		-
	1	EMPTY	PMH-005A	PMH-005B	EX-5"	-
	<u>m</u>	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-005A	PMH-005B	EX-5"	
	n	EMPTY	PMH-005A	PMH-005B	EX-5"	-
	0	CKT-316	PMH-005A	PMH-005B	EX-5"	
	a	EMPTY	PMH-005B	PMH-006A	EX-5"	
	b	EMPTY	PMH-005B	PMH-006A	EX-5"	_
	c	EMPTY	PMH-005B	PMH-006A	EX-5"	• .
	d	EMPTY	PMH-005B	PMH-006A	EX-5"	
	е	EMPTY	PMH-005B	PMH-006A	EX-5"	1
	f	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-005B	PMH-006A	EX-5"	-
	g	EMPTY	PMH-005B	PMH-006A	EX-5"	
_	h	EMPTY	PMH-005B	PMH-006A	EX-5"	
6	i	EMPTY	PMH-005B	PMH-006A	EX-5"	TYPE-4
	i	EMPTY	PMH-005B	PMH-006A	EX-5"	
	k	CKT-216	PMH-005B	PMH-006A	EX-5"	
	1	EMPTY	PMH-005B	PMH-006A	EX-5"	
	1		PMH-005B	PMH-006A	EX-5"] ·]
·	m	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-005B	PMH-006A	EX-5"	
	n o	CKT-316	PMH-005B	PMH-006A	EX-5"	
			DMIL OOGA	PMH-006B	EX-5"	
	a .	EMPTY	PMH-006A PMH-006A		EX-5"	,
	<u>b</u>	EMPTY		PMH-006B		
	C	EMPTY	PMH-006A PMH-006A	PMH-006B	EX-5"	-
	d	EMPTY		PMH-006B	EX-5"	
-	e	EMPTY	PMH-006A	PMH-006B	EX-5"	_
	f	EMPTY	PMH-006A	PMH-006B	EX-5"	
	g	EMPTY	PMH-006A	PMH-006B		
	h	EMPTY	PMH-006A	PMH-006B	EX-5"	
7	i	EMPTY	PMH-006A	PMH-006B	EX-5"	TYPE-3
	J	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-006A	PMH-006B	EX-5"	-
·	k	EMPTY	PMH-006A	PMH-006B	EX-5"	-
	1 1	CKT-216	PMH-006A	PMH-006B	EX-5"	-
	m	EMPTY	PMH-006A	PMH-006B	EX-5"	; -
	n	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-006A	PMH-006B	EX-5"	
	0	EMPTY	PMH-006A	PMH-006B	EX-5"	
	р	CKT-316	PMH-006A	PMH-006B	EX-5"	
	a	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-006B	PMH-006C	EX-5"	
	b	EMPTY	PMH-006B	PMH-006C	EX-5"	The state of the s
	С	EMPTY	PMH-006B	PMH-006C	EX-5"	
	d	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-006B	PMH-006C	EX-5"	T
8	e	EMPTY	PMH-006B	PMH-006C	EX-5"	TYPE-6A
	f	EMPTY	PMH-006B	PMH-006C	EX-5"	111 0/1
		EMPTY	PMH-006B	PMH-006C	EX-5"	=
	g		<u> </u>			-
	h	CKT-316	PMH-006B	PMH-006C	EX-5"	1

NOTES:

1. SEE DRAWING E-000/3CF89/RNK ARRANGEMENT.

SEWERAGE AND WATER BOARD
OF NEW ORLEANS

INSTALLATION OF TWO 60-HERTZ FEEDERS

FROM THE CARROLLTON WATER PLANT TO DRAINAGE PUMPING STATION 1

DUCTBANK SCHEDULE CONTRACT 6248

DR. JAMES BADON		\sim \sim
LAST EDIT JULY 12, 2013	HOPP !	Dorler
ск.	GENERAL SU	IPERINTENDENT
APQ USBY	DWC No	5058 - P24
SCALE AS SHOWN	DWG. NO.	J0J0 - 124
DATE JAN. 29, 2013	SET NO.	SHEET NO. 25 OF 30

		DUCTBANK	SCHE	DULE	<u> </u>	
TAG	С.	CIRCUIT	FRIM	7.27	SIZE	DUCTBANK ARRANGEMENT
	a	EMPTY	PMH-006C	PMH-007A	EX-5"	
	b	EMPTY	РМН-006С	PMH-007A	EX-5"	
	c	EMPTY	PMH-006C	PMH-007A	EX-5"	
	d	EMPTY	PMH-006C	PMH-007A	EX-5"	
	е	EMPTY	PMH-006C	PMH-007A	EX-5"	
	f	EMPTY	PMH-006C	PMH-007A	EX-5"	
,	g	EMPTY	PMH-006C	PMH-007A	EX-5"	
	h *	EMPTY	PMH-006C	PMH-007A	EX-5"	
9	i	EMPTY	РМН-006С	PMH-007A	EX-5"	TYPE 4
-	-	EMPTY	PMH-006C	PMH-007A	EX-5"	
	k	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-006C	PMH-007A	EX-5"	
<u> </u>	1	EMPTY	PMH-006C	PMH-007A	EX-5"	
Ì	m	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-006C	PMH-007A	EX-5"	
	n	EMPTY	PMH-006C	PMH-007A	EX-5"	
-	0	CKT-316	PMH-006C	PMH-007A	EX-5"	
<u> </u>						
	а	CAPPED	PMH-007A	PMH-007B	EX-5"	
ŀ	b	CAPPED	PMH-007A	PMH-007B	EX-5"	
-		CAPPED	PMH-007A	PMH-007B	EX-5"	
-	C					
}	d	CAPPED	PMH-007A	PMH-007B	EX-5"	
	e	CAPPED	PMH-007A	PMH-007B	EX-5"	,
-	f	CAPPED	PMH-007A	PMH-007B	EX-5"	
-	g	CAPPED	PMH-007A	PMH-007B	EX-5"	
10	h	CAPPED	PMH-007A	PMH-007B	EX-5"	
	i	CAPPED	PMH-007A	PMH-007B	EX-5"	TYPE 3
	j	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-007A	PMH-007B	EX-5"	I IIFE 3
	k	CAPPED	PMH-007A	PMH-007B	EX-5"	
	1	CKT-216	PMH-007A	PMH-007B	EX-5"	
ļ	m	EMPTY	PMH-007A	PMH-007B	EX-5"	
1	n	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-007A	PMH-007B	EX-5"	,
	0	EMPTY	РМН-007А	PMH-007B	EX-5"	
	p	CKT-316	PMH-007A	PMH-007B	EX-5"	
	a	EMPTY	PMH-007B	PMH-007C	EX-5"	
Ī	ь	EMPTY	PMH-007B	PMH-007C	EX-5"	
- 1	c	EMPTY	PMH-007B	PMH-007C	EX-5"	
	d ,	EMPTY	PMH-007B	PMH-007C	EX-5"	
Ì	e	EMPTY	PMH-007B	PMH-007C	EX-5"	1
•	f	EMPTY	PMH-007B	PMH-007C	EX-5"	<u>'</u>
	g	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-007B	PMH-007C	EX-5"	1
}	h	EMPTY	PMH-007B	PMH-007C	EX-5"	1
11	; ;	EMPTY	PMH-007B	PMH-007C	EX-5"	TYPE 4
11	i	EMPTY	PMH-007B	PMH-007C	EX-5"	
	J 1-	CKT-217	PMH-007B	PMH-007C	EX-5"	
	<u>k</u>			<u> </u>	·	,
	<u> </u>	EMPTY	PMH-007B	PMH-007C	EX-5"	
· .	<u>m</u>	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-007B	PMH-007C	EX-5"	
	i n	EMPTY	PMH-007B	PMH-007C	EX-5"	
٠.	n	CKT-318	PMH-007B	PMH-007C	EX-5"	

· T		DUCTBANK	SCHE	DULE		חווחדחווו
TAG	С.	CIRCUIT	FROM	7/7	SIZE	DUCTBANK ARRANGEMENT
	a	EMPTY	PMH-007C	PMH-008A	EX-5"	·
	b	EMPTY	PMH-007C	PMH-008A	EX-5"	
	c	EMPTY	PMH-007C	PMH-008A	EX-5"	
	d	EMPTY	PMH-007C	PMH-008A	EX-5"	
	е	EMPTY	PMH-007C	PMH-008A	EX-5"	
	f	EMPTY	PMH-007C	PMH-008A	EX-5"	
	g	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-007C	PMH-008A	EX-5"	
12	h	EMPTY	PMH-007C	PMH-008A	EX-5"	TYPE-4
12	i	EMPTY	PMH-007C	PMH-008A	EX-5"	111 6 4
	j	EMPTY	PMH-007C	PMH-008A	EX-5"	
	k	CKT-217	PMH-007C	PMH-008A	EX-5"	
	1	EMPTY	PMH-007C	PMH-008A	EX-5"	
	m	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-007C	PMH-008A	EX-5"	*
,	n	EMPTY	PMH-007C	PMH-008A	EX-5"	N.
	» O	CKT-316	PMH-007C	PMH-008A	EX-5"	
		EMPTY	PMH-008A	PMH-008B	EX-5"	
}	<u>a</u>	EMPTY			EX-5"	
}	<u>b</u>	EMPTY	PMH-008A	PMH-008B	<u> </u>	
	<u> </u>	EMPTY	PMH-008A	PMH-008B	EX-5"	
	d	EMPTY	PMH-008A	PMH-008B	EX-5" EX-5"	
	e	EMPTY	PMH-008A	PMH-008B	<u> </u>	
	f	EMPTY	PMH-008A	PMH-008B	EX-5"	
	<u>g</u>	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-008A	PMH-008B	EX-5"	,
13	<u>h</u>	EMPTY	PMH-008A	PMH-008B	EX-5"	TYPE-4
	i	EMPTY	PMH-008A	PMH-008B	EX-5"	
	<u>J</u>	EMPTY	PMH-008A	PMH-008B	EX-5"	
	k	CKT-217	PMH-008A	PMH-008B	EX-5"	
	<u>l</u> .	EMPTY	PMH-008A	PMH-008B	EX-5"	
	<u> </u>			PMH-008B	EX-5"	
	n	EMPTY	PMH-008A	PMH-008B	EX-5"	
}	O .	CKT-316	PMH-008A	PMH-008B	EX-5"	
<u></u>	a	EMPTY	PMH-008B	PMH-009A	EX-5"	
	b	EMPTY	PMH-008B	PMH-009A	EX-5"	
	c	EMPTY	PMH-008B	PMH-009A	EX-5"	
:	d	EMPTY	PMH-008B	PMH-009A	EX-5"	
	e	EMPTY	PMH-008B	PMH-009A	EX-5"	
. ,	f	EMPTY	PMH-008B	PMH-009A	EX-5"	
	g	EMPTY	PMH-008B	PMH-009A	EX-5"	
, .	h	EMPTY	PMH-008B	PMH-009A	EX-5"	l .
14	i			PMH-009A	EX-5"	TYPE-5
• 1	i	EMPTY	PMH-008B	PMH-009A	EX-5"	
	k k	EMPTY	PMH-008B	PMH-009A	EX-5"	
	, I	PF1G: 3-1000MCM(8KV), 4/0 G (600V)		PMH-009A	EX-5"	
	a	EMPTY	PMH-009A	PMH-010A	EX-5"	ı
	<u>b</u>	EMPTY	PMH-009A	PMH-010A	EX-5"	
	c	EMPTY	PMH-009A	PMH-010A	EX-5"	
	d	EMPTY	PMH-009A	PMH-010A	EX-5"	r
1	e	EMPTY	PMH-009A	PMH-010A	EX-5"	
	f	EMPTY	РМН-009А	PMH-010A	EX-5"	
15	g	EMPTY	PMH-009A	PMH-010A	EX-5"	TYPE-5
	h	EMPTY	PMH-009A	PMH-010A	EX-5"	
·	i	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-009A	PMH-010A	EX-5"	
	j	EMPTY	PMH-009A	PMH-010A	EX-5"	
	k	EMPTY	PMH-009A	PMH-010A	EX-5"	
1		PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-009A	PMH-010A	EX-5"	
()			_		_	

SEE DRAWING E-003 ARRANGEMENT.




SEWERAGE AND WATER BOARD OF NEW ORLEANS INSTALLATION OF TWO 60-HERTZ FEEDERS FROM THE CARROLLTON WATER PLANT
TO DRAINAGE PUMPING STATION 1 DUCTBANK SCHEDULE CONTRACT 6248

Legh Delen RAL SUPERINTENDENT
RAL SUPERINTENDENT
<u> </u>
o. 5058 – P25

TAG	С.	CIRCUIT	FRIIM	7.17	SIZE	DUCTBANK ARRANGEMENT
	a ·	EMPTY	PMH-010A	PMH-010B	EX-5"	
	b	EMPTY	PMH-010A	PMH-010B	EX-5"	
	С	EMPTY	PMH-010A	PMH-010B	EX-5"	
	d	EMPTY	PMH-010A	PMH-010B	EX-5"	
	e	EMPTY	PMH-010A	PMH-010B	EX-5"	
16	f	EMPTY	PMH-010A	PMH-010B	EX-5"	
	g	EMPTY	PMH-010A	PMH-010B	EX-5"	
	h	EMPTY	PMH-010A	PMH-010B	EX-5"	
	i	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-010A	PMH-010B	EX-5"	TYPE 5
	j	EMPTY	PMH-010A	PMH-010B	EX-5"	
	k	EMPTY	PMH-010A	PMH-010B	EX-5"	
		PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-010A	PMH-010B	EX-5"	- -
	a	EMPTY	PMH-010B	 PMH-011A	EX-5"	
	b	EMPTY	PMH-010B	PMH-011A	EX-5"	
	c	EMPTY	PMH-010B	PMH-011A	EX-5"	-
	d	EMPTY	PMH-010B	PMH-011A	EX-5"	1
	e	EMPTY	PMH-010B	PMH-011A	EX-5"	1
	f	EMPTY	PMH-010B	PMH-011A	EX-5"	-
17			PMH-010B	PMH-011A	EX-5"	TYPE 5
	g h	EMPTY	PMH-010B	PMH-011A	EX-5"	
	<u>h</u>	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-010B	PMH-011A	EX-5"	-
	1 :		PMH-010B	PMH-011A	EX-5"	
	1-	EMPTY	PMH-010B	PMH-011A	EX-5"	
	<u>k</u> 	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-010B	PMH-011A	EX-5"	
	a	EMPTY	PMH-011A	PMH-011B	EX-5"	
	b	EMPTY	PMH-011A	PMH-011B	EX-5"	
	С	EMPTY	PMH-011A	PMH-011B	EX-5"	,
	d	EMPTY	PMH-011A	PMH-011B	EX-5"	
	е	EMPTY	PMH-011A	PMH-011B	EX-5"	
•	f	EMPTY	PMH-011A	PMH-011B	EX-5"	TYPE 5
18	g	EMPTY	PMH-011A	PMH-011B	EX-5"	
	h	EMPTY	PMH-011A	PMH-011B	EX-5"	
]. · i	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-011A	PMH-011B	EX-5"	
				•	-	1
	j	EMPTY	PMH-011A	PMH-011B	EX-5"	.
	j k	EMPTY	PMH-011A	PMH-011B	EX-5" EX-5"	
	j k I		PMH-011A			- -
	1	EMPTY PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-011A PMH-011A	PMH-011B PMH-011B	EX-5"	
		EMPTY PF1G: 3-1000MCM(8KV), 4/0 G (600V) EMPTY	PMH-011A PMH-011A PMH-011B	PMH-011B PMH-011B PMH-012A	EX-5" EX-5"	
	a b	EMPTY PF1G: 3-1000MCM(8KV), 4/0 G (600V) EMPTY EMPTY	PMH-011A PMH-011A PMH-011B PMH-011B	PMH-011B PMH-011B PMH-012A PMH-012A	EX-5" EX-5" EX-5"	
	a b c	EMPTY PF1G: 3-1000MCM(8KV), 4/0 G (600V) EMPTY EMPTY EMPTY	PMH-011A PMH-011B PMH-011B PMH-011B PMH-011B	PMH-011B PMH-011B PMH-012A PMH-012A PMH-012A	EX-5" EX-5" EX-5" EX-5"	
	a b c d	EMPTY PF1G: 3-1000MCM(8KV), 4/0 G (600V) EMPTY EMPTY EMPTY EMPTY EMPTY	PMH-011A PMH-011B PMH-011B PMH-011B PMH-011B PMH-011B	PMH-011B PMH-011B PMH-012A PMH-012A PMH-012A PMH-012A PMH-012A	EX-5" EX-5" EX-5" EX-5" EX-5"	
19	a b c	EMPTY PF1G: 3-1000MCM(8KV), 4/0 G (600V) EMPTY EMPTY EMPTY EMPTY EMPTY EMPTY	PMH-011A PMH-011B PMH-011B PMH-011B PMH-011B PMH-011B PMH-011B	PMH-011B PMH-011B PMH-012A PMH-012A PMH-012A PMH-012A PMH-012A PMH-012A	EX-5" EX-5" EX-5" EX-5" EX-5" EX-5"	
19	a b c d e f	EMPTY PF1G: 3-1000MCM(8KV), 4/0 G (600V) EMPTY EMPTY EMPTY EMPTY EMPTY EMPTY EMPTY EMPTY	PMH-011A PMH-011B PMH-011B PMH-011B PMH-011B PMH-011B PMH-011B PMH-011B	PMH-011B PMH-011B PMH-012A PMH-012A PMH-012A PMH-012A PMH-012A PMH-012A PMH-012A	EX-5" EX-5" EX-5" EX-5" EX-5" EX-5" EX-5"	TYPF 5
19	a b c d e f	EMPTY PF1G: 3-1000MCM(8KV), 4/0 G (600V) EMPTY EMPTY EMPTY EMPTY EMPTY EMPTY EMPTY EMPTY EMPTY	PMH-011A PMH-011A PMH-011B PMH-011B PMH-011B PMH-011B PMH-011B PMH-011B PMH-011B	PMH-011B PMH-011B PMH-012A PMH-012A PMH-012A PMH-012A PMH-012A PMH-012A PMH-012A PMH-012A	EX-5" EX-5" EX-5" EX-5" EX-5" EX-5" EX-5" EX-5"	TYPE 5
19	a b c d e f	EMPTY PF1G: 3-1000MCM(8KV), 4/0 G (600V) EMPTY	PMH-011A PMH-011B PMH-011B PMH-011B PMH-011B PMH-011B PMH-011B PMH-011B PMH-011B	PMH-011B PMH-011B PMH-012A	EX-5" EX-5" EX-5" EX-5" EX-5" EX-5" EX-5" EX-5" EX-5"	TYPE 5
19	a b c d e f	EMPTY PF1G: 3-1000MCM(8KV), 4/0 G (600V) EMPTY	PMH-011A PMH-011B PMH-011B PMH-011B PMH-011B PMH-011B PMH-011B PMH-011B PMH-011B PMH-011B	PMH-011B PMH-011B PMH-012A	EX-5"	TYPE 5
19	a b c d e f	EMPTY PF1G: 3-1000MCM(8KV), 4/0 G (600V) EMPTY	PMH-011A PMH-011B PMH-011B PMH-011B PMH-011B PMH-011B PMH-011B PMH-011B PMH-011B	PMH-011B PMH-011B PMH-012A	EX-5" EX-5" EX-5" EX-5" EX-5" EX-5" EX-5" EX-5" EX-5"	TYPE 5

:		DUCTBANK	SCHE	DULE		
TAG	C.	CIRCUIT	FRIM	7.27	SIZE	DUCTBANK ARRANGEMENT
	a	EMPTY	PMH-012A	PMH-012B	EX-5"	
1	b	EMPTY	PMH-012A	PMH-012B	EX-5"	
	c	EMPTY	PMH-012A	PMH-012B	EX-5"	
	d	EMPTY	PMH-012A	PMH-012B	EX-5"	
<u>:</u>	e	EMPTY	PMH-012A	PMH-012B	EX-5"	
20	f	EMPTY	PMH-012A	PMH-012B	EX-5"	
	g	EMPTY	PMH-012A	PMH-012B	EX-5"	
<u>,</u>	h	EMPTY	PMH-012A	PMH-012B	EX-5"	
 	i	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-012A	PMH-012B	EX-5"	TYPE 5
;	i	EMPTY	PMH-012A	PMH-012B	EX-5"	-
	k	EMPTY	PMH-012A	PMH-01@B	EX-5"	
;	•	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-012A	PMH-012B	EX-5"	
		EMPTY	PMH-012B	PMH-012C	EX-5"	
	a b		PMH-012B	PMH-012C	EX-5"	<u>.</u>
		EMPTY	· · · · · · · · · · · · · · · · · · ·		EX-5"	-
, 	C	EMPTY	PMH-012B PMH-012B	PMH-012C PMH-012C	EX-5"	-
	d	EMPTY			EX-5"	
	e	EMPTY	PMH-012B	PMH-012C	EX-5"	·
21	f	EMPTY	PMH-012B PMH-012B	PMH-012C PMH-012C	EX-5"	TYPE 5
	g	EMPTY	PMH-012B	PMH-012C	EX-5"	
	h :	EMPTY 1000MCM(8KV) 4 (0 C (600V)		PMH-012C	EX-5"	
	1.	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-012B	PMH-012C	EX-5"	
:	<u> </u>	EMPTY	PMH-012B	PMH-012C	EX-5"	
	k	EMPTY PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-012B	PMH-012C	EX-5"	
		EMPTY	DMI 0120	DMU 012D	FV E"	
ļ	a L	EMPTY	PMH-012C	PMH-012D	EX-5"	<u>.</u>
-	b	EMPTY	PMH-012C	PMH-012D	EX-5"	
}	C	EMPTY	PMH-012C	PMH-012D	EX-5"	
	d	EMPTY	PMH-012C	PMH-012D	EX-5"	
,	e	EMPTY	PMH-012C	PMH-012D	EX-5"	TVDE 5
22	f	EMPTY	PMH-012C	PMH-012D	EX-5"	TYPE 5
	g ·	EMPTY	PMH-012C	PMH-012D	EX-5"	
	<u>h</u>	EMPTY	PMH-012C	PMH-012D	EX-5"	_
		PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-012C	PMH-012D	EX-5"	
	<u> </u>	EMPTY	PMH-012C	PMH-012D	EX-5"	- -
	k I	EMPTY PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-012C	PMH-012D PMH-012D	EX-5"	
	a	EMPTY	PMH-012D	PMH-013A	EX-5"	
	b	EMPTY	PMH-012D	PMH-013A	EX-5"	
	С	EMPTY	PMH-012D	PMH-013A	EX-5"	
	d	EMPTY	PMH-012D	PMH-013A	EX-5"	
	е	EMPTY	PMH-012D	PMH-013A	EX-5"	
23	f	EMPTY	PMH-012D	PMH-013A	EX-5"	and the same of th
£	g	EMPTY	PMH-012D	PMH-013A	EX-5"	TYPE 5
	<u></u>	EMPTY	PMH-012D	PMH-013A	EX-5"	
and the second s	h	DE4E 7 4000HOH/0HAA 4/0 0 (000H)	PMH-012D	PMH-013A	EX-5"	
en e	i	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	· · · · · · · · · · · · · · · · · · ·			•
en e	i j	EMPTY EMPTY	PMH-012D	PMH-013A	EX-5"	
	i j k			PMH-013A PMH-013A	EX-5"	



SEWERAGE AND WATER BOARD OF NEW ORLEANS


INSTALLATION OF TWO 60-HERTZ FEEDERS
FROM THE CARROLLTON WATER PLANT
TO DRAINAGE PUMPING STATION 1

DUCTBANK SCHEDULE CONTRACT 6248

DR. JAMES BADON LAST EDIT JULY 12, 2013 SCALE AS SHOWN DATE JAN. 29, 2013 SET NO. SHEET NO. 27 OF 30

	<u> </u>	DUCTBANK				DUCTDANIC
TAG	C.	CIRCUIT	FRIM	7/27	SIZE	DUCTBANK ARRANGEMENT
	a	EMPTY	PMH-013A	PMH-013B	EX-5"	
	b	EMPTY	PMH-013A	PMH-013B	EX-5"	
	С	EMPTY	PMH-013A	PMH-013B	EX-5"	
	d	EMPTY	PMH-013A	PMH-013B	EX-5"	
	е	EMPTY	PMH-013A	PMH-013B	EX-5"	
24	f	EMPTY	PMH-013A	PMH-013B	EX-5"	
	g	EMPTY	PMH-013A	PMH-013B	EX-5"	
	h	EMPTY	PMH-013A	PMH-013B	EX-5"	
	i	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-013A	PMH-013B	EX-5"	TYPE 5
	j	EMPTY	PMH-013A	PMH-013B	EX-5"	
	k	EMPTY	PMH-013A	PMH-013B	EX-5"	
		PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-013A	PMH-013B	EX-5"	
	a	EMPTY	PMH-013B	PMH-014A	EX-5"	
	b	EMPTY	PMH-013B	PMH-014A	EX-5"	
	С	EMPTY	PMH-013B	PMH-014A	EX-5"	
	d	EMPTY	PMH-013B	PMH-014A	EX-5"	· ·
	е	EMPTY	PMH-013B	PMH-014A	EX-5"	,
	f	EMPTY	PMH-013B	PMH-014A	EX-5"	
25	g	EMPTY	PMH-013B	PMH-014A	EX-5"	TYPE 5
	h	EMPTY	PMH-013B	PMH-014A	EX-5"	
	i	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-013B	PMH-014A	EX-5"	
	j	EMPTY	PMH-013B	PMH-014A	EX-5"	•
	k	EMPTY	PMH-013B	PMH-014A	EX-5"	-
	1 .	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-013B	PMH-014A	EX-5"	
	a	EMPTY	PMH-014A	PMH-014B	EX-5"	
	b	EMPTY	PMH-014A	PMH-014B	EX-5"	
	c	EMPTY	PMH-014A	PMH-014B	EX-5"	-
	d	EMPTY	PMH-014A	PMH-014B	EX-5"	
	a e	EMPTY	PMH-014A	PMH-014B	EX-5"	-
	f	EMPTY	PMH-014A	PMH-014B	EX-5"	TYPE 5
26	g	EMPTY	PMH-014A	PMH-014B	EX-5"	1
	$\frac{\mathcal{D}}{h}$	EMPTY	PMH-014A	PMH-014B	EX-5"	-
	i	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-014A	PMH-014B	EX-5"	- - -
	i	EMPTY	PMH-014A	PMH-014B	EX-5"	-
	k	EMPTY	PMH-014A	PMH-014B	EX-5"	1
	l e	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-014A	PMH-014B	EX-5"	
	a	EMPTY	PMH-014B	PMH-015A	EX-5"	
	b	EMPTY	PMH-014B	PMH-015A	EX-5"	
	c	EMPTY	PMH-014B	PMH-015A	EX-5"	
	d	EMPTY	PMH-014B	PMH-015A	EX-5"	1
	е	EMPTY	PMH-014B	PMH-015A	EX-5"	1
27	f	EMPTY	PMH-014B	PMH-015A	EX-5"	1
	g	EMPTY	PMH-014B	PMH-015A	EX-5"	TYPE 5
	h	EMPTY	PMH-014B	PMH-015A	EX-5"	-
	i	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-014B	PMH-015A	EX-5"	•
	i	EMPTY (COOK)	PMH-014B	PMH-015A	EX-5"	-
	$\frac{\mathbf{j}}{\mathbf{k}}$	EMPTY	PMH-014B	PMH-015A	EX-5"	•
· '	1	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-014B	PMH-015A	EX-5"	-
	L	1,0001)	·	1	,	

T		DUCTBANK	3011			DUCTBANK
AG	С.	CIRCUIT	FRIM	TI	SIZE	ARRANGEMENT
	a	EMPTY	PMH-015A	PMH-016A	EX-5"	
	b	EMPTY	PMH-015A	PMH-016A	EX-5"	
-	С	EMPTY	PMH-015A	PMH-016A	EX-5"	
	d	EMPTY	PMH-015A	PMH-016A	EX-5"	
	e	EMPTY	PMH-015A	PMH-016A	EX-5"	
28	f	EMPTY	PMH-015A	PMH-016A	EX-5"	
	g	EMPTY	PMH-015A	PMH-016A	EX-5"	
	h	EMPTY	PMH-015A	PMH-016A	EX-5"	TYPE 5
7	i	PF1F:3-1000MCM(8KV), 4/0 G (600V)	PMH-015A	PMH-016A	EX-5"	IIPE 3
1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1	j	EMPTY	PMH-015A	PMH-016A	EX-5"	
	<u>k</u>	EMPTY	PMH-015A	PMH-016A	EX-5"	
	<u>'I</u>	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-015A	PMH-016A	EX-5"	
	a	EMPTY	PMH-016A	PMH-016B	EX-5"	
	b	EMPTY	PMH-016A	PMH-016B	EX-5"	
ľ	c	EMPTY	PMH-016A	PMH-016B	EX-5"	
, [d	EMPTY	PMH-016A	PMH-016B	EX-5"	
ent.	е	EMPTY	PMH-016A	PMH-016B	EX-5"	
. `	f	EMPTY	PMH-016A	PMH-016B	EX-5"	
29	g	EMPTY	PMH-016A	PMH-016B	EX-5"	TYPE 5
	h	EMPTY	PMH-016A	PMH-016B	EX-5"	
:	i	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-016A	PMH-016B	EX-5"	
<u>.</u>	i	EMPTY	PMH-016A	PMH-016B	EX-5"	
	k	EMPTY	PMH-016A	PMH-016B	EX-5"	
·	* 1	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-016A	PMH-016B	EX-5"	
	a	EMPTY	PMH-016B	PMH-016C	EX-5"	
	ь	EMPTY	PMH-016B	PMH-016C	EX-5"	
Ì	c	EMPTY	PMH-016B	PMH-016C	EX-5"	
	d	EMPTY	PMH-016B	PMH-016C	EX-5"	
ŀ	е	EMPTY	PMH-016B	PMH-016C	EX-5"	
	f	EMPTY	PMH-016B	PMH-016C	EX-5"	TYPE 5
30	g	EMPTY	PMH-016B	PMH-016C	EX-5"	
	h	EMPTY	PMH-016B	PMH-016C	EX-5"	
ļ	1	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-016B	PMH-016C	EX-5"	
	i	EMPTY	PMH-016B	PMH-016C	EX-5"	
	k	EMPTY	PMH-016B	PMH-016C	EX-5"	
.]	<u> </u>	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-016B	PMH-016C	EX-5"	, .
	a	EMPTY	PMH-016C	PMH-017A	EX-5"	
ŀ	<u>b</u>	EMPTY	PMH-016C	PMH-017A	EX-5"	
-	c	EMPTY	PMH-016C	PMH-017A	EX-5"	1
	d	EMPTY	PMH-016C	PMH-017A	EX-5"	1
:	<u>е</u>	EMPTY	PMH-016C	PMH-017A	EX-5"	1
31	c	EMPTY	PMH-016C	PMH-017A	EX-5"	· ·
	g	EMPTY	PMH-016C	PMH-017A	EX-5"	TYPE 5
	h	EMPTY	PMH-016C	PMH-017A	EX-5"	1.
	i	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-016C	PMH-017A	EX-5"	*
	i	EMPTY	PMH-016C	PMH-017A	EX-5"	1
: 3 3	k	EMPTY	PMH-016C	PMH-017A	EX-5"	1
		PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-016C	PMH-017A	EX-5"	1
·].	•					-



			Cookii iiok		
SEWERA	GE	AND	WATER	BOA	\RD
)F 1	1EW	ORLEANS	5	


INSTALLATION OF TWO 60-HERTZ FEEDERS FROM THE CARROLLTON WATER PLANT TO DRAINAGE PUMPING STATION 1

DUCTBANK SCHEDULE CONTRACT 6248

DR. JAMES BADON		ο Λ.		
LAST EDIT JULY 12, 2013	Jeseph !	Daken		
CK.	GENERAL SUPERINTENDENT			
SCALE AS SHOWN	DWG. No.	5058 - P27		
DATE JAN. 29, 2013	SET NO.	SHEET NO. 28 OF 30		

		DUCTBANK	SCHE	DULE	······································	
TAG	С.	CIRCUIT	FRIM	7/7	SIZE	DUCTBANK ARRANGEMENT
	a	EMPTY	PMH-017A	PMH-018A	EX-5"	
ļ.,	<u>b</u>	EMPTY	PMH-017A	PMH-018A	EX-5"	
	С	EMPTY	PMH-017A	PMH-018A	EX-5"	
	d	EMPTY	PMH-017A	PMH-018A	EX-5"	
	е	EMPTY	PMH-017A	PMH-018A	EX-5"	
32	f	EMPTY	PMH-017A	PMH-018A	EX-5"	<u> </u>
	g	EMPTY	PMH-017A	PMH-018A	EX-5"	•
	<u>h</u>	EMPTY	PMH-017A	PMH-018A	EX-5"	TYPE 5
	i	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-017A	PMH-018A	EX-5"	ITPE 3
· .	j	EMPTY	PMH-017A	PMH-018A	EX-5"	
	k	EMPTY (2001)	PMH-017A	PMH-018A	EX-5"	
	1	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-017A	PMH-018A	EX-5"	:
	a	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-018A	PMH-018B	EX-5"	
	<u>b</u>	EMPTY	PMH-018A	PMH-018B	EX-5"	
	c	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-018A	PMH-018B	EX-5"	i i
33	<u>d</u>	EMPTY	PMH-018A	PMH-018B	EX-5"	
-	<u>e</u> .	EMPTY	PMH-018A	PMH-018B	EX-5"	TYPE 7
	f	CKT-304	PMH-018A	PMH-018B	EX-5"	
	a	CKT-204	PMH-018B	PMH-018B	EX-5"	-
Ī	b	EMPTY	PMH-018B	PMH-018C	EX-5"	
	ı C	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-018B	PMH-018C	EX-5"	1
34	d	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-018B	PMH-018C	EX-5"	
	е	EMPTY	PMH-018B	PMH-018C	EX-5"	TYPE 7
	f	CKT-304	PMH-018B	PMH-018C	EX-5"	
	a	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-018C	PMH-019A	EX-5"	
	b	EMPTY	PMH-018C	PMH-019A	EX-5"	
	С	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-018C	PMH-019A	EX-5"	
35	d	CKT-204	PMH-018C	PMH-019A	EX-5"	
	е	EMPTY	PMH-018C	PMH-019A	EX-5"	TYPE 7
	f	CKT-304	PMH-018C	PMH-019A	EX-5"	<u>.</u>
	а	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-019A	PMH-020A	EX-5"	
	b	EMPTY	PMH-019A	PMH-020A	EX-5"	
	C	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-019A	PMH-020A	EX-5"	
36	d	CKT-204	PMH-019A	PMH-020A	EX-5"	
	e	CKT-204	PMH-019A	PMH-020A	EX-5"	TYPE 7
•	a	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-020A	PMH-020B	EX-5"	
<u> </u>	b	EMPTY	PMH-020A	PMH-020B	EX-5"	
^- T	С	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-020A	PMH-020B	EX-5"	TYPE 8
37	d	CKT-204	PMH-020A	PMH-020B	EX-5"	1
	e	EMPTY	PMH-020A	PMH-020B	EX-5"	
	f	CKT-304	PMH-020A	PMH-020B	EX-5"	
38	a	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-020B	PMH-020C	EX-5"	
	b	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-020B	PMH-020C	EX-5"	TYPE 8
ļ	c	CKT-202	PMH-020B	PMH-020C	EX-5"	1155 0
· · · ·	d	CKT-302	PMH-020B	PMH-020C	EX-5"	
_	<u>u</u>			[WIT 0200	<u> </u>	

TAG	C.	CIRCUIT	FROM	7.27	SIZE	DUCTBANK ARRANGEMEN	
39 a b c d	CKT-202	PMH-020C	PMH-021A	EX-5"			
	b	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-020C	PMH-021A	EX-5"	1	
		PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-020C	PMH-021A	EX-5"	TYPE 8	
	CKT-302	PMH-020C	PMH-021A	EX-5"			
· ·			D. III. 0044		EV E"		
40	a	EMPTY	PMH-021A	PMH-022A	EX-5"	_	
40	b	EMPTY	PMH-021A	PMH-022A	EX-5"	TYPE 8	
.	С	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-021A	PMH-022A	EX-5"		
	d	PF1G:3-1000MCM(8KV), 4/0 G (600V)	PMH-021A	PMH-022A	EX-5"		
	a	EMPTY	PMH-022A	PMH-022B	EX-5"		
41	b	EMPTY	PMH-022A	PMH-022B	EX-5"	1.	
	c	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-022A	PMH-022B	EX-5"	TYPE 8	
	d	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-022A	PMH-022B	EX-5"		
			D. III. 000D				
	a	EMPTY	PMH-022B	PMH-022C	EX-5"	4	
,	b	EMPTY	PMH-022B	PMH-022C	EX-5"		
1	С	ENTERGY: 3-750MCM (5KV), 350MCM G (600V)		PMH-022C	EX-5"		
	<u>d</u>	EMPTY	PMH-022B	PMH-022C	EX-5"		
42	e ^r	EMPTY	PMH-022B	PMH-022C	EX-5"	TYPE 9	
.2	f	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-022B	PMH-022C	EX-5"	_	
	g	EMPTY	PMH-022B	PMH-022C	EX-5"		
	h	ENTERGY: 3-750MCM (5KV), 350MCM G (600V)	PMH-022B	PMH-022C	EX-5"		
	i	EMPTY	PMH-022B	PMH-022C	EX-5"		
j	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-022B	PMH-022C	EX-5"	1		
	•	EMPTY	PMH-022C	PMH-0107A	EX-5"		
43	EMPTY	PMH-022C	PMH-0106A	EX-5"	_		
		ENTERGY: 3-750MCM (5KV), 350MCM G (600V)		PMH-0105A	EX-5"		
		EMPTY	PMH-022C	PMH-0104A	EX-5"		
		EMPTY	PMH-022C	PMH-0103A	EX-5"		
	f	PF1F: 3-1000MCM(8KV), 4/0 G (600V)	PMH-022C	PMH-0107A	EX-5"	TVDC 0	
	g	EMPTY	PMH-022C	PMH-0106A	EX-5"	TYPE 9	
		ENTERGY: 3-750MCM (5KV), 350MCM G (600V)		PMH-0105A	EX-5"		
	i	EMPTY	PMH-022C	PMH-0104A	EX-5"	1	
	i	PF1G: 3-1000MCM(8KV), 4/0 G (600V)	PMH-022C	PMH-0103A	EX-5"	1	



DESCRIPTION

SEWERAGE AND WATER BOARD
OF NEW ORLEANS

INSTALLATION OF TWO 60-HERTZ FEEDERS
FROM THE CARROLLTON WATER PLANT
TO DRAINAGE PUMPING STATION 1

DUCTBANK SCHEDULE CONTRACT 6248

DR. JAMES BADON

LAST EDIT JULY 12, 2013


CK.


GENERAL SUPERINTENDENT


DWG. NO. 5058 — P28

DATE JAN. 29, 2013 SET NO. SHEET NO. 29 OF 30

M










BY U.K.B. DATE 7/14/82 SUBJECT KOUTE OF FEEDER 306


FOR DETAILS AND REVISIONS SEE DWG Nº 1098-P-1-P-6, 1810-P-


SHEET NO. ____OF _____
























1. ALL EXISTING DRAINAGE STRUCTURES ARE TO BE REMOVED UNLESS NOTED OTHERWISE.

UNLESS NOTED OTHERWISE

3. ALL EXISTING STREET LIGHTS SHALL REMAIN UNLESS NOTED OTHERWISE.


4. EXISTING DRAIN LINES THAT CANNOT BE REMOVED SHALL BE FILLED WITH SAND AND PLUGGED BY THE CONTRACTOR.


2. THE ONLY ACCEPTABLE ALTERNATE TO S.D.P. IS R.C.P. (REINFORCED CONCRETE PIPE)




STRN	DESCRIPTION	INVERTS	
		UPPER	LOWE
	EASTBOUND	•	•
236	STA. 36+13 REQD. 36"x 308' SDP W/1 36"x 36"x 15" WYE	13.03	13.34
237	STA. 36+40 REQD. SDOCB	•	
238	STA. 36+38.5 REQD, 15"x5' SDP	15.59	14.09
239	STA. 34+59.5 REQD. STD. M.H. NO. 3	•	
240	STA. 34+61 REQD. 18"x 5' SDP	15.00	14.98
241	STA. 34+62.5 REQD. DVCB		
242	STA. 34+44.5 REQD. 36"x 31' SDP	13.03	13.00
243	STA. 34+01 REQD. VCB	:	
244	STA. 34+02.5 REQD. 15"x 5' SDP	15.17	15.12
246	STA. 34+16.5 REQD. 15"x 24' SDP W/1 15"x 15"x 15" WYE	15.12	15.00
248	EXIST. 42"x 46" SDP		
	WESTBOUND		
334	STA. 236+20 REQD. 30"x 304' SDP W/1 30"x 30"x 15" WYE	13.79	13.48
335	STA. 236+48 REQD. VCB	e - e	
336	STA. 236+46.5 REQD. 15"x 5' SDP	15.78	14.28
337	STA. 234+71 REQD. DVCB		
338	STA. 234+69.5 REQD. 15"x 5' SDP	16.02	16.00
339	STA. 234+68 REQD. STD. M.H. NO. 2		
340	STA. 234+51 REQD. 30"x 34' SDP	13.48	13.45
341	STA. 234+05 REQD. VCB		
342	STA. 234+06.5 REQD. 15"x 5' SDP	16.18	16.13
344	STA. 234+21 REQD. 15"x 26' SDP W/1 15"x 15"x 15" WYE	16.13	16.00
345	STA. 234+34 REQD. STD. M.H. NO. 2		

BEGIN WESTBOUND & P.O.C. STA. 233+99.83 = P.O.T. STA. 134+00.00-46.31' RT. EXIST. S&WB FOR 404 BEGIN EASTBOUND & P.O.C. STA. 33+99.61 = P.O.T. STA. 134+00.00-39.09" RT. SURVEY LINE REQ'D. ELEC. DUCTBANK ------REQ'D. ELEC. M.H. #5B SEE NOTE #3 SEE NOTES 1 & 2 SEE NOTES 1 & 2--f-024' E.B. & 0000 0000 Conc. EXIST. & REQ'D. R/W 0000 CONTRACTOR TO FURNISH AND INSTALL TWELVE (12)-6" SCHEDULE 40 PVC CONDUITS, ENCASED IN REINFORCED CONCRETE.
 TOP OF DUCTBANK SHALL BE THREE (3) FEET BELOW STREET GRADE, UNLESS OTHERWISE SPECIFIED. SEE PROFILE. 1 CURVE DATA ©CURVE DATA CONTRACTOR TO FURNISH AND INSTALL NEW MANHOLES AS PER S&WB DWG No. 1000-P5B. P.I. = 234+34.93 = P.O.T. 134+34.90-50.10' LT. SURVEY LINE Δ =03'37'22.9" RT. D=1'45' P.I. = 34+60.47 = P.O.T 134+60.58-33.15' RT. SURVEY LINE $\Delta = 07'48'13.1''$ RT. D=3'45" T = 103.55'T = 104.21' L = 208.10' R = 1527.89' e = 3.55' L = 207.03' R = 3274.04' e = 1.64P.C.=233+31.38 = P.O.T. 133+31.78-41.03' LT. SURVEY LINE P.T.=235+38.41 = P.O.T. 135+38.42-52.63' LT. SURVEY LINE P.C.=33+56.26 = P.O.T. 133+56.77-42.27' RT. SURVEY LINE P.T.=35+64.36 = P.O.T. 135+64.66-38.21' RT. SURVEY LINE








Nos.


DATE 5-28-82 SUBJECT Route Of Feeder 402/404 SHEET NO. 2 OF 4


BY_ 1.L.E.


From Power House # 2 JOB NO. CHKD. BY. D E St. Broadway Voffer. is over 90-45 St. Pinc St. Lowerline S. G. F. 14 71.5 54. Buroette 81+6-State St. Dr. St. Fern 81+33 79+76 College Ct. 73+ -Short 54. Auduson Cable Is Loid In Center Of Neutral Bround



























































AS-BUILT MAPS FOR OAK STREET RIVER STATION













AS-BUILT MAPS FOR PLANT FREQUENCY CHANGER







AS-BUILT MAPS FOR CARROLLTON FREQUENCY CHANGER









		BILL OF MATERIAL	
TEM		PESCEIPTION	WORK REQUIRED
		24KV SWITCHGEAD (SEE EQUIP. SPEC.)	MSTALL NEW
(2)		TRANSFORMER # 1, 7.5 MVA, 24KV/4160V.	INSTALL NEW
(3)		TRANSFORMER # 2, 7.5 MVA, 24KV/41GOV. (SEE EQUIP. SPEC.)	INSTALL NEW
4		6600 VOLT, 25 HZ, SWITCH GEAR (SEE EQUIP SPEC.)	INSTALL NEW
(E)	A CONTRACTOR OF THE CONTRACTOR	4160VOLT, GOHZ, GWITCHGEAR (GEE EQUIP, GPEC.)	INGTALL NEW
(b)		CONTROL PANEL, SECTIONS 1-4 (SEE EQUIPMENT SPEC.)	MODIFY & RELOCATE
<u>(7)</u>		CONTROL PANEL, SECTIONS, 5-9 (SEE E-QUIPMENT SPEC.)	INSTALL NEW
(B)		25HZ POWER PANEL, 120/240V, 1 P, 3W. 100 A MAIN CIRCUIT BREAKER 50."D" NOO-2-3AB SURFACE MOUNT, WITH NOOP BREAKERS	INSTALL NEW
(9)		GOHE LIGHTING PANEL, 120/240 V., 1P, 4W., 225A MAIN LUG ONLY SQ. "D" NQO-42-4L SUEFALE MOUNT, WITH NOOPBREAKER	install New
(10)		60HZ POWER PANEL, 120/2404, 3P, 4W, 400'A. MAIN CIRCUIT BREAKER 69. "D" HCN-2664-B WITH "FA" TYPE BRANCH BREAKERS	iustall new
(11)		TRANSFORMER # 3, 160 KVA, 4160-120/240V, 3PH, 60HZ DELTA-DELTA, DRY TYPE, INDOORS WITH (2) 21/2% TAPS ABOVE & BELOW, GROUNDED B" PHASE	NEW
(12).		FIELD CHEOSTAT, FC #1, GO HZ MACHINE	EXISTING - TO REMAIN (CLEAN CONTACTS & CHECK)
(13)		FIELD CHEOSTAT, FC#1, 25 HZ MACHINE	EXISTING - TO REMAIN (CLEAN CONTACTS & CHECK)
(14)		Battery Charger, Go He	EXISTING - TO BE RELOCATED
(B)		BATTERY CHARGER, POWER CONVERSION PRODUCTS (OR EQUAL) MODEL Nº RU-130-12 OPTIONS 1-2-4-5-7-8-11-14, EXCEPT 25 Hz.	NEW
(16)		BATTERY CHARGER TRANSFER GWITCH, 130VDC 2POLE, DOUBLE THROW NON FUSED 100AMP,	NEW
		SQUARE" D" CAT. # 82293 OR EQUAL	
			and the second s

TEM .	DESCRIPTION	WORK REGUIRED
(17)	TRANSFER SWITCH FOR CLOSING CIRCUITS, 130VDC, 2POLE, DOUBLE THROW, WITH 100AMP FUSES IN BOTH PRIMARIES. SQUARE "D" CAT. # 82253F OR EQUAL	NEW
(18)	DISTRIBUTION PANEL, FOR CLOSING CIRCUITS, 130VDC, 100 A, 16, 2W, MAIN LUGS ONLY GE # 240 NAB-8 POLES	NEW
(19)	DC FIELD SWITCHGEAR, 130 VDC	EXISTING - TO BE RELOCATED
20	FIELD RHEOSTAT, FC#2, GOHZ MACHINE	RECONDITION EXISTING EQUIP.
(21)	FIELD RHEOSTAT, FC #2,25HE MACHINE	RECONDITION EXISTING EQUIP
(22)	ROTOR RESISTOR FOR FC#2 STARTING MOTOR	EXISTING - TO
23	ROTOR RESISTOR FOR FC#1 STARTING MOTOR	EXISTING - TO REMAIN
(24)	DISTRIBUTION PANEL FOR TRIP CIRCUIT, BOVDC, 100A, 10, 2W, MAIN LUGS ONLY GE 240 NAB- 8 POLES	NEW
(25)	TRANSFER SWITCH FOR TRIP CIRCUITS, 130VPC, 2 POLE, DOUBLE THROW, WITH 100A FUSES IN BOTH PRIMARIES. SQUARE "D" CAT. \$ 52253F OR EQUAL	VEW
(26)	CIRCUIT BREAKER, 480, 3P, GOOA, MOLDED CASE MAGNETIC ONLY, FOR FC#2 STARTING MOTOR 200H.P., SQUARE "D" CAT. # LAL 36600 WITH ENCLOSURE # LAGOOF OR EQUAL	NEW
(27)	TRANSFORMER #T4, 225 KVA, 4160/480V., 3PH, GOHE., DRY TYPE, INDOOR, DELTA-W'E, WITH (2) 21/2% TAPS ABOVE & BELOW SQUARE "D" CAT. # 225T19H OR EQUAL	NEW Control of the Co
(28)	CURRENT METERING TRANSFORMER, 9TY. (3) 400/1 LINE CURRENT, 9TY (1) 100/1 NEUTRAL CURRENT, FOR 6600V, SPH, ZSHE, APPLICATION	FURNISHED BY SWITCHGEAR VENDOR
(29)	LIGHTNING ARRESTORS & SURGE CAPACITORS	EXISTING - YO REMAIN
(30)	METERING CURRENT TRANSFORMERS GTY (3) 800/5 LINE CURRENT GTY. (1) 200/5 NEUTRAL CURRENT	FURLISHED BY SWITCHGEAR VENDOR
(31)	LIGHTHING ARRESTORS & SURGE CAPACITORS	EXISTING - TO
201 1 201 1 201 1 201	CURRENT METERING TRANSFORMERS, 974. (3) 400/5	REMAIN FURNISHED BY
(22)	LINE CURRENT GTT. (1) 100/5 NEUTRAL CURRENT, FOR 4160V., 3PH, 60HZ APPLICATION	gwitchgear Vendor
(33)	CURRENT METERING TRANSFORMERS, 9TY. (3) 1200/5 LINE CURRENT GTY. (1) 200/5 NEUTRAL CURRENT FOR A160V., 3PH, GOHZ APPLICATION	FURNISHED BY SWITCHGEAR VENDOR
(34)	NEUTRAL GROUNDING RESISTOR FOR FC# 2, 25HZ	EXIGTING
(35)	NEUTRAL GROUNDING RESISTOR FOR FC#2, GOHE MACHINE	EXISTING - CHECKOU.
(36)	NEUTRAL GROUNDING RESISTOR FOR FC# 1,25HZ	EXISTING
(37)	HEUTRAL GROUNDING RESISTOR FOR FC# 1, GOHE MACHINE TERMINAL BOX, FC # 1 METERING	EXIGING - CHECKOUT & RECONNECT EXIGING
38	TERMINAL BOX, FC # 2 METERING	EXISTING
39	GROUND CONTACTOR, FC#1 GO HZ (SEE SPEC.)	NEW
40	WITH NEMA-12 ENCLOSURE TO BE THE PROPERTY OF T	NEW*
(41) (42)	GROUND CONTACTOR, FC # 2 GO HZ (SEE SPEC.) WITH NEMA-12 ENCLOSURE TRANSFORMER #5, 30 KVA, DRY TYPE, 6600V/120-240 1P, 25HZ, INDOOR,	NEW
43	RECTIFIER, 12.5 KW., OUTPUT 1304, 100A D.C., INPUT 240 V, 3P LZMARCHE A-28-100-1304	NEW
44>	BATTERY BANK, 130 V DC	RELOCATE EXISTING; FAB NEW RACK
45	LIGHTNING ARRESTORS & SURGE CAPACITORS FOR A1604, 3P, GOHE MOTOR PROTECTION (SEE SPEC.)	NEW
(46)	LIGHTHING ARRESTORS & SURGE CAPACITORS FOR 4100 V., 3P, 60 HE MOTOR PROTECTION (SEE SPEC.) FC #2	NEW
47	GROUND CONTACTOR FC#1 25 Hz (SEESPEC) WITH NEMA-12 ENCLOSURE	
(48)	GROUND CONTACTOR FC #2 25 HZ (SEE SPEC) WITH NEMA-12 ENCLOSURE	
49	METERINGCATIO	EXISTING - TO BE REMOVED
50	FIELD ADJUSTING RHEOSTAT - FC Z EXCITER	EXISTING
(BI)	FIELD ADJUSTING RHEOSTAT - FC EXCITER	EXISTING
52	GOHZ POWER PANEL, 120/240V, 3\$, 4W, 225A MAIN, 4200T	REMOVE EXISTINGE REPLACE W/NEW
53	MOTOR STARTER OIL PUMP # FC-1	EXISTING
54)	MOTOR STARTER OIL PUMP#FC-1	(NOTE-1) EXISTING (NOTE-1)

BILL OF MATERIAL

THE BEST OF (MY OR OUR) KNOWLEDGE AND BELIEF, THEY COMPLY WITH ALL CITY REQUIREMENTS, I AM (SUPERVISING, NOT SUPERVISING) THE WORK

I. EQUIPMENT TO BE REMOUNTED AS NECESSARY TO ACCOMODATE NEW HIGHER FLOOR IN CONTROL ROOM ONLY.

SEWERAGE AND WATER BOARD OF NEW ORLEANS

FREQUENCY CHANGER BLDG. EXPANSION

CARROLLTON STATION EQUIP. LOCATION PLAN & SCHED.

DR. R.M, CK. CRawler

PRELIMINARY

FOR APPROVAL

APPROVED AS NOTED

IL9-84 SW APPROVED FOR CONSTRUCTION 4/15/85 19

WINK DWG. No. 11-020684-P-1201

DRAWING ISSUE

SCALE NONE DATE 7-9-84 SETNO.

DWG. No. 4797- P-5 SHEET NO.

